

PAD MOUNT PRIMARY METERING CABINET REQUEST

COMPANY: _____ CONTACT NAME: _____

ADDRESS: _____ PHONE #: _____

E-MAIL: _____

INITIAL PURCHASE QTY: _____ ANNUAL USE QTY: _____

1. NOMINAL VOLTAGE OF THE ENCLOSURE:

- 15kV/95kV BIL
 25kV/125kV BIL

2. AMPERAGE:

- 200A
 600A
 OTHER _____

3. PHASE:

- 3 PHASE
 SINGLE PHASE

4. DIMENSION:

- 4690** 54"W x 54"D x 45"H (15kV ONLY)
 5454 54"W x 54"D x 52"H (15kV ONLY)
 7624 79"W x 54"D x 54"H
 7791 72"W x 56"D x 48"H

*ELECTRAK Sliding Shelf Feature

- 7950*** 79"W x 54"D x 58"H
 7990* 48"W x 54"D x 42"H (SADTEM/KYE Pack)
 7951** 79"W x 54"D x 58"H

**ELECTRAK Sliding Shelf Feature (Top Only)

5. BUSHINGS REQUIRED PER EACH PHASE:

- 200 AMP BUSHING WELL W/ BUSHING INSERT 600 AMP BUSHING
QTY: _____ LINE _____ LOAD QTY: _____ LINE _____ LOAD

6. ARE TRANSFORMERS REQUIRED: YES NO

VOLTAGE TRANSFORMERS:

PREFERRED MANUFACTURER: _____

TYPE: _____ PART # _____

PRIMARY/SECONDARY VOLTAGE: _____

CURRENT TRANSFORMERS:

PREFERRED MANUFACTURER: _____

TYPE: _____ PART # _____

VOLTAGE CLASS: _____

RATIO: _____

7. MOUNTING:

- CTS MOUNTED FROM THE CEILING AND VTS AT GROUND LEVEL (STANDARD)
 OTHER _____

8. DO YOU WANT PRIMARY CONNECTIONS BETWEEN THE BUSHING AND THE TRANSFORMERS?

- YES NO

PAD MOUNT PRIMARY METERING CABINET REQUEST

8. IS SECONDARY WIRING DESIRED? YES NO

*If Yes Please Attach Wiring Diagram With Wire Colors.

9. WIRE PREFERENCE:

#12 GUAGE THHN STRANDED (STANDARD)

OPTIONAL PLASTIC CONDUIT

#12 GUAGE THHN SOLID

OTHER _____

10. METER SOCKET REQUIRED? YES NO

*If Yes See Brooks Pre-Wired Meter Socket Request Form For Specific Meter Socket Requirements

9. Please specify other features, specifications and/or special needs:

*** Return to Brooks CSR Email OR orders@brooksupg.com**