



Optimizing Service Intervals and Witchcraft. There is a difference.


1





























11

... but there is one BIG thing missing








... so what does all this mean?




so how often should you conduct preventive maintenance?













so what happens if we do more preventive maintenance?












26


... let's look at all possible servicing or PM intervals






... so what should our servicing or PM interval be?








32


... don't believe me?











38

... but isn't this 'bathtub curve' rare? ... does it have anything to do with maintenance?

YES.


... we call the post-servicing hazard rate the rate of occurrence of failure after servicing (ROFAS).


... it is one of the *very few* times we see the stereotypical bathtub curve

40


... WO ... let's not get too carried away with this statistical magic


41







... it is more important to be a hunter of wear-out failure



























... but this CAN BE just the start ...






















... OK ... so you still really want to do the ROFAS stuff?














68

... to learn more about how to do this:

C. Jackson and B. Mailler, "Post-servicing failure rates: Optimizing preventive maintenance interval and quantifying maintenance induced failure in repairable systems," 2013 Proceedings Annual Reliability and Maintainability Symposium (RAMS), Orlando, FL, 2013, pp. 1-7, doi: 10.1109/RAMS.2013.6517681.

