



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R1025	5.6	Upright	SR	Fusible	1/2	Brass, Chrome, Black Plated, Bright Brass, Zinc Plated	135, 165, 212, 286 (57, 74, 100, 141)
R1026	8.0	Upright	SR	Fusible	1/2	Brass, Chrome, Black Plated, Bright Brass, Zinc Plated	135, 165, 212, 286 (57, 74, 100, 141)
R3117	8.0	Pendent	QR	Fusible	3/4	Brass, Chrome, Black Plated, Bright Brass, Zinc Plated, Lead	165, 212 (74, 100)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657 USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657 USA

FM Approvals Class: 2001, 2016

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR455326

Approval Granted: May 30, 2022

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

