Sengineer Report Water Hammer Control

RESIDENTIAL | COMMERCIAL | INDUSTRIAL

The Science

What causes water hammer

The Solution

How to control water hammer

The Selection

Products and services available

Supply Drainage Support Specialties

www.siouxchief.coi



TAKE THE FIELD.

Water Hammer Control

>> An Explanation of and Solution to Water Hammer

Water hammer can occur in any type of piping system– small, medium or large. Whether you are designing a residential condo project, a commercial office tower or an industrial laundry facility in a high-rise hotel, proper methods for water hammer control need to be employed during the design stages of construction. This Engineer Report will explain the physics of water hammer and the best methods of water hammer control for residential, commercial and industrial piping systems.

Table of Contents

1 The Science

The Physics of Water Hammer PG 5

The Damage PG 7

2 The Solution

2.1 Controlling Water Hammer PG 11

2.2 Arrester Sizing Guidelines PG 12

2.3 National Model Codes PG 13

2.4 Residential Arrester Sizing & Placement PG 14

2.5 Commercial Arrester Sizing & Placement PG 16

2.6 Industrial Arrester Sizing & Placement PG 18

3 The Selection

3.1 Sioux Chief Arresters PG 21

3.2 Residential Arresters PG 22

3.3 Commercial Arresters PG 24

3.4 Industrial Arresters PG 28

3.5 Comparison PG 30

4 The Appendix

4.1 Certifications PG 33

4.2 Case Study - Water Hammer from a Different Angle PG 36

4.3 Arrester Installations PG 40

4.4 Spec Sheets PG 46

Flowing water lines, like trains, are hard to stop quickly. While they can be stopped by a valve or faucet, the sudden stop no doubt results in a serious pressure surge. The analogy may seem extreme, yet the truth is every time a flowing water column is stopped abruptly, a small train wreck occurs in your water line. The longer the line, and the faster the flow, the more momentum the "train" will carry. Even though these collisions in your lines are small, their long-term effects can and will result in large-scale damage throughout the piping system.

The Science Explaining the Physics of Water Hammer

This section covers the physics of uncontrolled water hammer and its damaging effects as they pertain to any piping system. We also review the history of water hammer in plumbing systems, previous attempts to control water hammer, and why these methods failed.

What Is Water Hammer

The term "water hammer" is used to describe the pressure surges, audible noise and destructive forces associated with the transfer of kinetic energy into the piping system due to an abrupt change in velocity of a non-compressible fluid. For the purpose of this discussion, the non-compressible fluid is usually water, and the change in velocity usually occurs when the flowing water comes to a sudden and complete stop due to valve or faucet closure. Thus, in the equations below, the initial flowing velocity is always equal to the change in velocity. (Example: Initial flowing velocity is 8 feet per second and, when the flow is completely stopped, zero feet per second. The change in velocity is 8 - 0 or 8 fps, which is equal to the initial flowing velocity of 8 fps.)

The two main factors necessary to create water hammer in a piping system are the initial speed (velocity) of the flowing water and an abrupt change to this flowing water velocity. When a water column is stopped abruptly, the momentum force in the flowing water (kinetic energy) quickly transforms into a pressure rise within the pipe. The amount of force (KE ft/lbs) within the flowing water can be calculated by the formula for kinetic energy:

KE = 1/2 mv²

When considering KE within a piping system, the mass (m) can be substituted with the physics characteristics of water within a cylindrical pipe (i.e., specific weight, cross-sectional area, length, plus gravitational constant). Velocity (v) is calculated in feet per second (fps), which can easily be converted from the known gpm and pipe size. For a plumbing or piping system, the kinetic energy formula can be expressed as this:

$\mathbf{KE} = .97 \mathbf{X} \mathbf{A} \mathbf{X} \mathbf{L} \mathbf{X} \mathbf{v}^2$

A = Cross sectional area of pipe I.D. in square feet

L = Length of effective pipe in feet

 \mathbf{v} = Velocity of flowing water in feet per second

Since we can calculate the kinetic energy, we can also calculate the actual "pressure rise" within a piping system by using Joukowsky's Formula:

pr = wav / 144g

- pr = Pressure rise above flow pressure (psig)
- w = Specific weight of liquid (water = 62.4 lbs/ft ³)
- a = Velocity of pressure wave in feet per second (fps)(4000 4500 fps in metal pipe)
- **v** = Change in flow velocity in feet per second (fps)
- g = Gravitational constant (32.2 fps²)

1. Valve closed - static water



2. Valve open - moving water



3. Valve closes - WATER HAMMER



What Is Water Hammer Continued

By plugging in the given factors on the previous page, the formula shows us that the pressure rise in metal pipe due to a sudden change in velocity is approximately 60 times the original flow velocity in feet per second. Thus, a common 1/2" supply line, flowing at 6 fps, can generate a pressure rise of 360 psig above and beyond the flow pressure itself (right). The resultant shock wave bounces back and forth within the supply line until it reaches a point of relief in a larger main where the initial velocity was much slower.

Within plastic pipe systems, such as PVC, CPVC, and PEX, the modulus of elasticity is much less than copper or steel pipe, and thus the velocity of the pressure wave is slower. This results in a lower pressure rise in plastic pipe versus metal pipe, given the same parameters. However, an equal amount of kinetic energy exists in both plastic and metal systems. So where does the energy go if it does not result in the same type of pressure rise? The answer is the excessive energy is absorbed into the plastic piping system by the instantaneous expansion of the pipe, fittings and appurtenances within the system. Historically, water hammer damage to the pipe itself is not the main concern, because the pipe can generally handle these expansions and contractions. Rather, it is the wide variety of fitting systems for plastic pipe (i.e., solvent weld, mechanical crimp, pinch clamps, expansion fittings, both made from brass and hard plastic) that are at risk.

Why Air Chambers Don't Work

It used to be thought that an air chamber, or capped stand pipe, was an effective solution to controlling water hammer. However, within an air chamber, nothing separates the air from the water. It only takes a few short weeks before the air is absorbed into the water, leaving the air chamber waterlogged and completely ineffective. Laboratory tests confirm that the air is depleted by simple air permeation and by interaction between static pressure and flow pressure. In the diagram shown, (right) notice the difference in water level between "Static Line Pressure" and "Post-cycle Static Level."



Product Damage Due to Water Hammer

All valves, fittings and appurtenances in the shock wave's path feel the full brunt of this pressure rise each and every time the flow is abruptly stopped. It would be a big mistake to consider only the excessive pressure effects on the pipe itself, because the pipe is not a primary concern for failure. Rather, all other plumbing products within the system are at risk. Certainly, in due time, uncontrolled water hammer will cause premature failure in the following products:

WATER HEATERS SAFETY RELIEF VALVES (T&P VALVES) PRESSURE REDUCING VALVES (PRVs) BACKFLOW PREVENTERS FAUCETS SOLENOID VALVES FITTINGS HANGERS & BRACKETS

Water Heaters

Expansion and contraction caused by thermal changes has always been thought of as the main cause of tank failure. This may very well be true, but failure is exacerbated by water hammer. Although the evidence of water hammer damage is not as apparent, both residential and commercial water heaters fail prematurely from this excessive force. Repetitive shock waves traveling through the tank can eventually cause the tank lining to crack, leaving the steel tank exposed to rust and failure.

Safety Relief Valves (T&P Valves)

Although the T&P is designed to relieve excess pressure, its simple spring design is not adequate to handle the rapid shock wave created by uncontrolled water hammer, which can come and go in a few milliseconds. The valve is left to absorb the damaging shock wave. On occasion, depending on the circumstances, the valve may "pop off" as a result of water hammer. However, this is not the intended purpose of this device, and could lead to failure when the safety feature is needed most.





Product Damage Due to Water Hammer Continued

Pressure Reducing Valves (PRVs)

Although PRVs are usually located at the opposite end of a quick-closing termination valve, the resultant shock wave will still affect a PRV. Repetitive shock waves can eventually damage the mechanics of the device, rendering it useless and allowing excessive main pressure to pass. Water hammer has also been known to crack the brass castings and seats of the device.



Backflow Preventers

Just like PRVs, backflow preventers are subject to the same water hammer problems. However, the damage and problems can be more complicated and costly with BFPs. Excess water hammer pressure downstream is inconveniently dumped by the BFPs relief valves each and every time a shock wave is created.



Faucets

Of course, faucets are susceptible to damage from the water hammer created by their own quick-closing design. Expensive faucet cartridges have been known to fail or even crack in half due to water hammer.



Solenoid Valves

Electronic solenoid valves in both residential and commercial clothes washers, dishwashers and ice makers are very susceptible to water hammer damage. The solenoid valve is usually the first (and by far the most common) part to be replaced on these appliances. Solenoid valves are now prominent on commercial flush valves and lav faucets. Do not be fooled by some manufacturers' claims of "slow-closing" solenoid valves. For both regular and slow-closing valves, the speed of closure and subsequent change in flow is still very abrupt and destructive.







Solvent weld fittings for PVC and CPVC systems, as well as various mechanical joint systems for PEX pipe, are especially vulnerable to water hammer damage. Water hammer puts undue stress on directional fittings in two ways. First, the excess internal pressure can easily exceed the ASTM pressure rating for the system. Second, water hammer often causes pipe movement, which results in external stress on tees and elbows.

Hangers & Brackets

Uncontrolled water hammer is by far the primary cause of loose pipe hangers and failed pipe support systems. This causes additional noise from loose rattling pipes and sometimes total pipe failure when hangers are completely dislodged.



The most efficient and widely used type of arrester is the piston style. Its simplicity of design is cost efficient to produce, yet few moving parts assures high quality and longevity.



The Solution Exploring the Solution to Water Hammer

This section discusses the best method of water hammer control by means of an engineered water hammer arrester. It also covers the three common sizing and placement methods used in the plumbing industry for residential, commercial, and industrial applications, along with the applicable codes and standards.

Controlling Water Hammer

The most effective means of controlling water hammer is the installation of an engineered water hammer arrester. An engineered arrester employs a measured, compressible cushion of air or gas which is permanently separated from the water. When a valve closes abruptly, the moving water column is displaced up into the arrester, compressing the permanent air charge until all the momentum of the moving water is safely dissipated, allowing the column to slow down calmly, preventing the development of water hammer.

Historically, manufacturers have employed a rubber diaphragm, a metal bellows or a piston with o-rings to separate the air from the water. Although all of these types of devices have been around for many years, the most efficient and widely used type of arrester is the piston style. Its simplicity of design is cost efficient to produce, yet few moving parts promote high quality and longevity.

ASSE Testing and Certification

To ensure quality, the arrester product standard most widely specified by engineers worldwide is ASSE 1010. The American Society of Sanitary Engineering (ASSE) requires rigorous testing and annual factory quality audits in order for the manufacturer to display the ASSE Certification on their arresters. In addition, national model codes in the USA and Canada require ASSE 1010 Certification on any arrester installed.



Water flows through system



Methods of Sizing

Three different methods of sizing are outlined below for each industry segment. Choose the sizing method most appropriate for your project and refer to the following pages for more details on that method.

RESIDENTIAL



Single-Fixture & Private Plumbing Groups Applications: Not just for homes. Plumbing fixtures in homes, duplexes, apartments, condominiums, motels, hotels and military housing. Sizing/Placement Guideline: Point-of-use AA size arrester on both hot and cold lines. Place on ice makers, dishwashers, washing machines and



Arrester Group: Any ASSE 1010 Certified AA size arrester. Various connection size and type are for the installer's convenience.



COMMERCIAL





Buildings

Multi-fixture Plumbing Groups

Applications: Plumbing fixtures in office buildings, retail, schools, hospitals, correctional facilities and public buildings.

Sizing/Placement

Guideline: The properly sized arrester corresponds to the total number of fixture units on each hot and cold branch line. Place each arrester at end of the branch line.



Arrester Group: Any ASSE 1010 Certified A, B, C, D, E, or F size arrester. Various connection size and type are for the installer's convenience.



INDUSTRIAL





Institutions

Up-Feed Pump Systems

Large Industrial Piping Systems

Applications: Industrial equipment, food processing, commercial laundry, up-feed pump systems, irrigation and waste treatment systems.

Sizing/Placement Guideline: To size an

arrester for industrial applications, use the Industrial Equation, custom sizing the arrester given the system information of a particular project. A computer spreadsheet version of this equation is also available.



Arrester Group: Large industrial size arresters, 200-400 cubic inch size.



Residential & Commercial Model Code Requirements

The UPC, IPC, IRC model codes, and now the National Plumbing Code of Canada, all require the installation of ASSE 1010 Certified Water Hammer Arresters on all quick-closing valves to control water hammer in both residential and commercial plumbing applications.



2018 UNIFORM PLUMBING CODE (UPC/IAPMO)

609.10 Water Hammer: Building water supply systems where quick-acting valves are installed shall be provided with water hammer arrester(s) to absorb high pressures resulting from the quick closing of these valves. Water hammer arresters shall be approved mechanical devices that comply with ASSE 1010 or PDI-WH 201 and shall be installed as close as possible to quick-acting valves.

609.10.1 Mechanical Devices: Where listed mechanical devices are used, the manufacturer's specifications as to location and method of installation shall be followed.



2018 INTERNATIONAL PLUMBING CODE (IPC/ICC)

604.9 Water Hammer: The flow velocity of the water distribution system shall be controlled to reduce the possibility of water hammer. A water-hammer arrestor shall be installed where quick-closing valves are utilized. Waterhammer arrestors shall be installed in accordance with the manufacturer's specifications. Water-hammer arrestors shall conform to ASSE 1010.

2018 INTERNATIONAL RESIDENTIAL CODE (IRC/ICC)

P2903.5 Water Hammer: The flow velocity of the water distribution system shall be controlled to reduce the possibility of water hammer. A water-hammer arrestor shall be installed where quick-closing valves are utilized. Water-hammer arrestors shall be installed in accordance with the manufacturer's instructions. Waterhammer arrestors shall conform to ASSE 1010



NATIONAL PLUMBING CODE OF CANADA 2010 (NPC/NRCC)

A·2.6.1.9.(1) Water Hammer Prevention:

Water hammer is a buildup of pressure in a length of horizontal or vertical pipe that occurs when a valve or faucet is closed suddenly. The longer the pipe and the greater the water velocity, the greater the pressure exerted on the pipe, which can be many times the normal static water pressure and be sufficient to damage the piping system. Since air chambers made from a piece of vertical pipe do not provide acceptable protection, pre-manufactured water hammer arresters are required to address this potential problem. 2.2.10.15. (1) Water Hammer Arresters: Water hammer arresters shall conform to ASSE 1010.

NOTE: The three model codes above make no exception to their arrester requirements for various piping materials. Both plastic and metal piping systems are required to have water hammer arresters installed to protect not only the pipe itself, but all fittings, valves and appurtenances that would otherwise be adversely affected by uncontrolled water hammer.

Residential Installation Guide

To control water hammer in most residential applications, install ASSE 1010 Certified AA size water hammer arresters on both the hot and cold supply lines serving washing machines, dishwashers, ice makers and quickclosing tub/shower valves to satisfy the minimum requirements of all model codes. Arresters should be installed within six feet of each culprit valve, and can be installed at any angle. All AA size arresters that are ASSE Certified are equal in arrester capacity, regardless of connection size and type. The various AA arrester connection types are simply for the convenience of the installer.



Recommended



Dishwasher









Tub/Shower

Ice Maker

Use as Needed



Lav/Sink



Toilet Ballcock

>> Placement

Arresters should be installed within six feet of each culprit valve, and can be installed at any angle.

Access Boxes With Integral Arresters

In addition to the many connection types, ASSE Certified AA arresters are also available as integral parts of the supply valves installed in access boxes, such as laundry and ice maker boxes. These products make installation simple and easy for the plumber because the arresters are already the right size and factory installed in the right place for the application.

For the same reasons, they make code enforcement simple for the plumbing inspector. When access boxes with integral arresters are installed, the correct size and placement of the arresters is accomplished every time.



Residential Irrigation

Zone valves in residential lawn sprinkler systems are common culprits of severe water hammer. This uncontrolled pressure surge can be very damaging not only to the sprinkler system components but also to the backflow preventer and other components of the plumbing system.

To prevent water hammer, install the specified ASSE 1010 Certified arrester within six feet of the zone valve or group of valves:

On 3/4" service line: One B size arrester

On 1" service line: One C size arrester





Commercial Installation Guide

For water hammer control in commercial plumbing applications, such as water closets, urinals and lavs in public restrooms, use the following sizing and placement guidelines based on fixture units.

DETERMINING ARRESTER SIZE BY FIXTURE UNITS

The National Plumbing Code offers this definition of fixture unit: "A fixtureunit is a quantity in terms of which the load producing effects on the plumbing system of different kinds of plumbing fixtures are expressed on some arbitrarily chosen scale." The fixture unit values shown in Table 1 below represent the standard ratings used by engineers to size water distribution systems as well as water hammer arresters. "Public" fixtures, as referred to in Table 1 below, are fixtures found in public rest rooms, office buildings and other places where each fixture is open and accessible for use at all times.

MULTIPLE FIXTURE BRANCH LINES

On many types of applications, a single arrester must serve multiple fixtures. In these cases, the total fixture units should be determined for all fixtures served by the branch line where the arrester is to be placed. Once the fixture units for the branch line have been totaled, choose the appropriate arrester by matching fixture units in the table (below) to the arrester size with the corresponding fixture unit capacity. If the total number of fixture units has a fraction, it should be rounded to the next largest whole number. In addition, if the flow pressure at the fixture exceeds 65 psig, the next largest size water hammer arrester should be used.



ARRESTER PLACEMENT ON MULTI-FIXTURE BRANCH LINES

Once the correct size arrester has been determined, the final concern is placement of the arrester within the system. Arrester placement depends on the length of the branch line on which the arrester is to be installed, which can be divided into two cases which are described below:

TABLE 1

	FIXTURE TYPE OF SUPPLY CONTROL		FIXTURE UNITS					
FIXTURE			PUBLIC			PRIVATE		
	CONTROL	TOTAL	C.W.	H.W.	TOTAL	C.W.	H.W.	
Water Closet 1.66 PF	Flush Valve	8	8	-	5	5	-	
Water Closet 1.66 PF	Flush Tank	5	5	-	2.5	2.5	-	
Pedestal Urinal 1.06 PF	Flush Valve	4	4	-	-	-	-	
Stall or Wall Urinal	Flush Valve	4	4	-	-	-	-	
Stall or Wall Urinal	Flush Tank	2	2	-	-	-	-	
Lavatory	Faucet	2	11/2	11/2	1	1	1	
Bathtub	Faucet	4	2	3	2	11/2	11/2	
Shower Head	Mixing Valve	4	2	3	2	1	2	
Bathroom Group	Flush Valve Closet	-	-		8	8	3	
Bathroom Group	Flush Valve Closet	-	-		6	6	3	
Separate Shower	Mixing Valve	-	-		2	1	2	
Service Sink	Faucet	3	3	3	-	-	-	
Laundry Tubs (1-3)	Faucet	-	-	-	3	3	3	
Combination Fixture	Faucet	-	-	-	3	3	3	
Clothes Washer	Solenoid Valves	-	-	-	4	3	3	
Dishwasher	Solenoid Valve	-	-	-	1.5	-	1.5	
Ice Maker	Solenoid Valve	-	-	-	1	1	-	

TABLE 2

ARRESTER SIZE	AA	А	В	С	D	E	F
FIXTURE UNITS	1-4	5-11	12-32	33-60	61-113	114-154	155-300

BRANCH LINES OF 20 FEET OR LESS (See Figure 1)

Place arrester at the end of the branch line within 6 feet of the last fixture served, as illustrated on page 15.

BRANCH LINES OVER 20 FEET (See Figure 2)

Calculate fixture units for each 20-foot section separately and place an arrester at the end of each 20-foot section (within 6 feet of the last fixture served in that section) as illustrated in Figure 2 on page 15.





Industrial Installation Guide

©1996 Sioux Chief Manufacturing

The formula below was developed by Sioux Chief as an alternative method of sizing the necessary arrester capacity for large commercial and industrial applications. In these situations, the formula shown below can be used to select the correct size arrester for any given system.

$$C = \frac{1.5 \times L \times V^2}{D^2 \times (Pf + 14.7) \times Y}$$

L = Effective pipe length (in feet)

V = Change in Velocity (in gallons per minute)

 \mathbf{D} = I.D. of pipe (in inches)

Pf = Flow pressure (PSIG)

Y = A function of Pma/Pfa (see graph on following page)

Pm = Maximum allowable pressure (PSIG)

C = Required arrester capacity (in cubic inches)

EXAMPLE

Description of System

L Length of pipe = 200 feet. This is the effective pipe length of the branch line serving the hammering valve. This is where the energy is. As the same flow goes through larger pipes, such as the main trunk line, the energy calculates to be very low and inconsequential.

V Change in velocity = 120 gpm. We can usually assume that our initial flow rate (120 gpm) is equal to the change in velocity, because when we shut off a valve completely, the resultant velocity is always 0. Thus, 120 - 0 = 120. However, if the valve does not completely shut off, and the velocity changes from 120 gpm to 40 gpm, V would then equal 120 - 40 = 80 gpm. This is the most critical factor in the formula, and usually the most difficult to get on an existing installation.

D Pipe size = 3". Try to use the actual I.D. of the pipe if possible. The nominal size of the pipe will get you close to the right answer, but the actual I.D. size will be more accurate.

P_f Flow pressure = 60 psig. This variable is the gauge pressure at the valve when the valve is on. In the formula, we add 14.7 psi (atmospheric pressure) to the gauge pressure to convert it to absolute or **P**_{fa}.

Pm Maximum allowable pressure = 150 psi. This variable represents the pressure to which the sized arrester will limit the shock. It can vary depending on input from the plumber or yourself, but 150 psig is generally used because most plumbing equipment is rated at 150 psig. Also we have observed little or no water hammer noise at this level. In the formula, we add 14.7 psi (atmospheric pressure) to the gauge pressure to convert it to absolute or **Pma**.

FORMULA CALCULATIONS

First we should calculate for the Y Factor. This variable answers the question "What is the maximum allowable pressure in relationship to the flow pressure? Is it twice as much?" To determine this you must divide the maximum allowable pressure (remember to add 14.7 to convert **P**m to **P**ma) by the flow pressure (remember to add 14.7 to convert **P**f to **P**fa).

Pma / Pfa = (150 + 14.7) / (60 + 14.7) = 2.2**Pma / Pfa** = 2.2

Next, look at the graph (on following page) and find the intersection of **2.2** and the **Y** curve. Follow that point straight down to the X axis to read **35**. In this example, **Y** = **35**.

Now that you have all the variables, do the original calculation:

$$C = \frac{1.5 \times 200 \times 120^2}{D^2 \times (Pf + 14.7) \times Y}$$

C = **184** in³

ARRESTER SIZING

Choose an arrester that is equal to or larger than the necessary capacity in your calculation. In this example, a 200 cubic inch industrial arrester is the correct choice.

ARRESTER PLACEMENT

Place arrester on supply side of culprit valve within the last 5% of supply line to the valve. In this example, place arrester within 10 feet of the valve.



After Placement

The pressurized permanently separated with a dual o-ring piston from the water





Section 5

The Selection

Exploring the Selection of Water Hammer Arresters

This chapter will explain why the Sioux Chief line of residential, commercial and industrial water hammer arresters is the number one arrester selected by engineers and specifiers throughout North America and around the world.

Sioux Chief Arresters

Sioux Chief Mfg. leads the plumbing industry in the development and manufacture of water hammer arresters for any and all applications.

Piston Design. Simplicity of design allows for the highest quality and longest life of any arrester type. Endurance tested to 500,000 cycles without failure.

Made in America. All arresters are manufactured in the

USA, utilizing all-American copper and brass materials.

Green Footprint. 100% recyclable copper and brass, sourced from the Midwest, efficiently produced and distributed from the Heart of America, creates the smallest carbon footprint of any arrester brand on the market.

Connection Options. Sioux Chief's unique ability to provide a wide variety of connection options saves the installer time and money, while eliminating costly transition joints. Integral arrester connection types are designed specifically for the type of piping system used.

Certified. Arresters are certified by ASSE to the ASSE 1010 Standard, satisfying the requirements of all model codes. ASSE performs yearly factory audits to ensure their high-quality standards are maintained.

Expertise. Sioux Chief has experts on staff with computer software to help you with new project sizing, as well as troubleshooting existing installations.

Acceptance. Millions of Sioux Chief arresters have been specified and installed throughout the country and around the world over the past 25 years.

RESIDENTIAL MiniRester[™]

COMMERCIAL HydraRester®









MiniRester[™]

All MiniResters are approved for sealed wall installations with no access panel required, and are certified by ASSE as AA size to the ANSI/ASSE 1010-2004 Standard. MiniResters may be installed at any angle.

STRAIGHTS

- · Straight sweat arresters are compatible with press-fitting systems, such as Viega ProPress™ and all push-fitting systems
- · MIP thread arresters install on any new rough-in or retrofit installation with 1/2" FIP fittings
- CPVC solvent weld arresters install on ¹/₂" CPVC tube or fittings in rough-in or retrofit applications
- PEX MiniResters are available with F1807 crimp, F1960 expansion, and F3347 metal press connections†
- All 660-G Series MiniResters use brass components certified as no-lead. MiniResters made with copper and plastic components only are naturally no lead compliant

TEES

· Hose tee arresters install on washing machine supply valves or directly to washing machine

TUB/SHOWER TEES

· Sweat branch arresters install easily on sweat tub/shower valves

PEX TEES

- · ASTM F1807 PEX Tee†
- · ASTM F1960 PEX Tee†

COMPRESSION TEES

 Install in-line on ice maker lines, lav or dishwasher supply tubes

FEMALE COMPRESSION TEE

· Installs either between stub out and supply stop, or between supply stop and supply tube for faucets, dishwashers, toilets or ice makers

ITEM NO.	DESCRIPTION	NO LEAD	MIN. QTY.	CASE QTY.
STRAIGHT				
660-SB	1/2" Male Sweat	Х	50	50
660-S	1/2" Male Sweat, Clamshell	Х	6	6
660-G2B	1/2" MIP Thread	Х	50	50
660-G2	1/2" MIP Thread, Clamshell	Х	6	6
660-V82B	1/2" Male CPVC	Х	50	50
660-V82	1/2" Male CPVC, Clamshell	Х	6	6
660-X2B	1/2" F1807 PEX, Straight	Х	50	50
660-GVPX2B	1/2" F3347 PEX Press	Х	50	50
660-WG2B	1/2" F1960 PEX	Х	50	50
TEE		,		
660-HB	3/4" Female Swivel Hose Thread × 3/4" Male Hose Thread Tee		25	25
660-H	3/4" Female Swivel Hose Thread × 3/4" Male Hose Thread Tee, Clamshell		6	6
660-TKB	Female Swivel Ballcock Nut × Male Ballcock Thread Tee		25	25
660-TK	Female Swivel Ballcock Nut × Male Ballcock Thread Tee, Clamshell		6	6
TUB/SHOWER TEE				
660-TS	1/2" Male Sweat Open End Branch × 1/2" Female Sweat Tee	х	25	25
660-TS8	1/2" x 8" Stub Out × 1/2" Female Sweat Tee	x	25	25
660-TS88	1/2" x 8" Double Stub Out × 1/2" Female Sweat Tee	x	25	25
660-TSX	1/2" Male Sweat × 1/2" PEX F1807 Crimp Tee	Х	25	25
660-TSX88	1/2" x 8" Double Stub Out × 1/2" F1807 PEX Tee	х	25	25
PEX TEE		1		
660-GTW2B	1/2" PEX Cold Expansion Tee F1960	Х	25	25
660-GTX2B	1/2" PEX Crimp Tee F1807	х	25	25
660-GTX2	1/2" PEX Crimp Tee F1807, Clamshell	х	6	6
COMPRESSION TE	Ξ			
660-GTC0B	1/4" O.D. Compression Tee For Ice Maker Tube	х	25	25
660-GTC0	1/4" O.D. Compression Tee For Ice Maker Tube, Clamshell	Х	6	6
660-GTC1B	3/8" O.D. Compression Tee For Supply Tube	х	25	25
660-GTC1	3/8" O.D. Compression Tee For Supply Tube, Clamshell	x	6	6
FEMALE COMPRES	SSION TEE			
660-GTR0B	1/4" O.D. Comp. × 1/4" O.D. Female Comp.	х	25	25
660-GTR0	1/4" O.D. Comp. × 1/4" O.D. Female Comp., Clamshell	х	6	6
660-GTR1B	3/8" O.D. Comp. × 3/8" O.D. Female Comp.	Х	25	25
660-GTR1	3/8" O.D. Comp. × 3/8" O.D. Female Comp. Clamshell	х	6	6
				_
660-GTRB	5/8" 0.D. Comp × 5/8" 0.D. Female Comp. 5/8" 0.D. Comp. × 5/8" 0.D.	х	25	25

† Note on ASTM PEX Fitting Standards:

20

ASTM F1807: Metal Insert Fittings Utilizing a Copper Crimp Ring

ASTM F1960: Cold Expansion Fittings with PEX Reinforcing Rings ASTM F3347: Metal Press Insert Fittings with Factory Assembled Stainless Steel Press Sleeve



3 Section

HydraRester[®]

Acceptance. The HydraRester has been specified and installed more than any other arrester model, making it the leading arrester in the country and around the world.

Certified. The American Society of Sanitary Engineering has certified the HydraRester to the ANSI/ASSE1010- 2004 Standard.

Tested. HydraRester has been cycle tested at U.S. Testing Laboratories to withstand 10,000 shock cycles. Factory tested to withstand 500,000 cycles without failure (654-C tested).

Healthcare. Copper is well known for its antimicrobial properties. Plus, the HydraRester's piston design eliminates the possibility of stagnant water columns that can create ideal conditions for bacterial growth such as legionella.

Green. The HydraRester is made from 100% recyclable copper, sourced right here in the Midwest. Combined with Sioux Chief's automated production efficiencies, it gives the HydraRester the lowest carbon footprint of any arrester on the market.

Compatible. HydraRester is available in five connection options – MIP, Sweat, PEX Crimp, PEX Expansion or CPVC – saving the installer time and money. HydraRester male sweat fittings are compatible with press-fitting systems, such as Viega ProPress[™], and all push-fitting systems.

Compact Size. Allows for installation in a 2×4 wall cavity.

Installation Angle. May be installed at any angle.

Sealed Wall Installation. Approved for installation with no access panel required.



Cold-rolled and Spun-losed Chamber End

Pressurized Air Cushion

Dual O-ring, PP Piston



Seamless Cold Formed Reduction



ITEM NO.	CONN. SIZE	UNIT SIZE	DIMENSIONS LENGTH X WIDTH	FIXTURE UNIT VALUE	CUBIC INCH VOLUME	MIN. QTY.	CASE QTY.
MIP THREAD)						
652-A	1⁄2"	Α	6½" x 1³⁄8"	1-11	5	1	16
653-B	3⁄4"	В	8¾" x 1¾"	12-32	7	1	16
654-C	1"	С	11" x 1¾"	33-60	11	1	16
655-D	1"	D	101⁄8" x 21⁄8"	61-113	20	1	4
656-E	1"	E	125⁄8" x 21⁄8"	114-154	29	1	4
657-F	1"	F	151⁄8" x 21⁄8"	155-330	36	1	4
MALE SWEA	T/PRESS	FITTING					
652-AS	1⁄2"	Α	8½" x 1¾"	1-11	5	1	16
653-BS	3⁄4"	В	10 x 13⁄8"	12-32	7	1	16
654-CS	1"	С	12½" x 1¾"	33-60	11	1	16
655-DS	1"	D	11" x 21⁄8"	61-113	20	1	4
656-ES	1"	E	13½" x 2½"	114-154	29	1	4
657-FS	1"	F	16" x 21⁄8"	155-330	36	1	4
CPVC SOCK	ET ASTM I	284 6	t				
652-AC	1⁄2"	Α	7½" x 1¾"	1-11	5	1	16
653-BC	3⁄4"	В	9½" x 1¾"	12-32	7	1	16
654-CC	1"	С	12" x 1¾"	33-60	11	1	16
PEX CRIMP	ASTM F18	807 †					
652-AX	1⁄2"	Α	6½" x 1⅔"	1-11	5	1	16
653-BX	3⁄4"	В	8¾" x 1¾"	12-32	7	1	16
654-CX	1"	С	11" x 13⁄8"	33-60	11	1	16
PEX EXPANS	ION ASTN	1 F1960	t				
652-AWG	½"	Α	6½" x 1⅔"	1-11	5	1	16
653-BWG	3⁄4"	В	8¾" x 1¾"	12-32	7	1	16
654-CWG	1"	С	11" x 1¾"	33-60	11	1	16

† NOTE: PEX and CPVC connection specifications are limited to those called out in their respective ASTM Standards for Fittings.



Connection Types



Sweat/Press Fitting



MIP



CPVC



PEX Crimp/Expansion

Cold Water - First Half

 3 Lavs =
 4½ FU

 1 Urinal =
 4 FU

 TOTAL =
 8½ FU

 Requirement =
 A-Size

Cold Water - Second Half

1 Urinal =	4 FU
3 Water Closets =	24 FU
TOTAL =	28 FU
Requirement =	B-Size

Hot Water

3 Lavs =	41⁄2 FU
Requirement =	A-Size



Cold Water Right

2 Water Closets =	16 FU
2 Urinals =	8 FU
TOTAL =	24 FU
Requirement =	B-Size

Cold Water Left

3 Lavs =	41⁄2 FU
Requirements =	A-Size

Hot Water

3 Lavs =	41⁄2 FU
3 Water Closets =	A-Size





Cold Water Right

2 Water Closets =	16 FU
2 Urinals =	8 FU
TOTAL =	24 FU
Requirements =	B-Size

Cold Water

3 Lavs =	41⁄2 FU
Requirements =	A-Size

Hot Water

3 Lavs =	41⁄2 FU
Requirements =	A-Size



3 Section

MegaRester[™]

Industrial Applications. Perfect for industrial equipment, commercial laundry equipment, food-processing, irrigation and waste-treatment systems.

Choice of Tube Wall Material. Available in copper or 316 stainless steel for any application.

Adjustable On Site. Liquid-filled gauge and air filler valve for job site charging.

Customized Per Application. Fit your specific job requirements. Call Sioux Chief for custom, expert sizing and placement recommendations.

COPPER

- Dual o-ring piston lubricated with Dow 111 FDA-approved silicone compound
- Cast brass flange or wrought copper male thread fitting with lead-free solder joints
- 4" nominal Type L copper tube barrel
- · 600-lb. (40-bar) liquid filled gauge
- Factory air charge

STAINLESS STEEL

- Dual o-ring piston lubricated with Dow 111 FDA-approved silicone compound
- Cast brass flange or wrought copper male thread fitting with lead-free solder joints
- 4" nominal Type L copper tube barrel
- 600-lb. (40-bar) liquid filled gauge
- Factory air charge



ITEM NO.	CONNECTION SIZE AND TYPE	VOLUME (IN ³)	HEIGHT (IN)	MIN. QTY.	CASE QTY.				
COPPER									
658-1503	3" MIP (ANSI B1.20.1)	150	23.25	1	1				
658-2002	2" MIP (ANSI B1.20.1)	200	29.25	1	1				
658-2004	4" MIP (ANSI B1.20.1)	200	24.50	1	1				
658-4004	4" MIP (ANSI B1.20.1)	400	42.50	1	1				
658-4004F2	4" Class 150 Flange (ANSI B16.24)	400	41.75	1	1				
STAINLESS STEEL									
658S2002	2" MIP (ANSI B1.20.1)	200	24.25	1	1				
658S2004F2	4" Class 150 Flange (ANSI B16.24)	200	24.00	1	1				
658S4004F2	4" Class 150 Flange (ANSI B16.24)	400	40.00	1	1				



Sioux Chief vs. the Competition

Sioux Chief's superior design and machining processes have allowed plumbers and contractors to bid jobs with confidence, knowing the product not only wins on paper, it performs in the field where it counts.







Cross Reference Guide

MANUFACTURERER (Trade Name)	AA	A	В	C	D	E	F
SIOUX CHIEF (HydraRester)	660 series	652-A	653-B	654-C	655-D	656-E	657-F
JOSAM (Absorbotron)	N/A	75001	75002	75003	75004	75005	75006
J.R. SMITH (Hydrotrol)	N/A	5005	5010	5020	5030	5040	5050
PPP (MM series, SC series)	MM-500 series	SC500	SC750	SC1000	SC1250	SC1500	SC2000
TYLER/WADE (Shokstop)	N/A	W-5	W-10	W-20	W-50	W-75	W-100
WATTS (AA = 05 series, A-F = 15 series)	05 series	15 - ½"	15 - ¾"	15 - 1"	15 - 1 ¼"	15 - 1 ½"	15 - 2"
ZURN (Shocktrol, Z-1700 series)	N/A	100	200	300	400	500	600



Appendix >> Certifications, Articles, Reports and Specifications

This section has technical information on certification, an explanation of the 2018 IRC Code change, case studies of water hammer situations, as well as engineer status reports. In addition, specification sheets for all Sioux Chief arresters are included.

What it Means to get Certified

In order for an arrester manufacturer to get their arrester products fully certified by ASSE, they must first go through rigorous performance and endurance testing by an accredited test lab. Each arrester model must pass this 10,000 cycle test. Once the testing is successfully completed, the test results are then reviewed by the ASSE Seal Board Committee before a full certification is issued. In addition to all of this testing and certification, ASSE performs annual factory audits to insure continuous quality with all arrester production. Annual Renewal Certificates are then issued for manufacturers that properly fulfill their ASSE requirements.





P2903.5 Water Hammer Arrestors

CHANGE TYPE: Modification

CHANGE SUMMARY: A water hammer arrestor is now required where quick-closing valves are used in the water distribution system.

2018 CODE: P2903.5 Water hammer. The flow velocity of the water distribution system shall be controlled to reduce the possibility of water hammer. A water hammer arrestor shall be installed where quick-closing valves are utilized. Water hammer arrestors shall be installed in accordance with the manufacturer's instructions. Water-hammer arrestors shall conform to ASSE 1010.

CHANGE SIGNIFICANCE: Water hammer describes the effects of hydraulic shock resulting from a sudden change in the velocity of water flowing through a pipe. The effect is not always audible, but when it is, it sounds similar to a hammer striking a pipe. There is potential for damage to the piping system over time, resulting in premature failure requiring repair or replacement.

Prior to the 2009 IRC, the code required installation of water hammer arrestors where quick-closing valves were utilized. In the 2009 through 2015 editions of the IRC, that mandatory requirement has not appeared. Instead, the code has only directed that the possibility of water hammer needs to be reduced by controlling the flow velocity of the water distribution system and, when installed, water hammer arrestors needed to follow the manufacturer's instructions and were required to conform to ASSE 1010. The prescriptive language for determining when a water hammer arrestor was required has been missing. However, the *International Plumbing Code (IPC)* language has not changed since its inception and has always required a water hammer arrestor when quick-closing valves are used. The sudden increase in flow velocity that causes water hammer is typically related to quick-closing valves. A quick-closing valve is

P2903.5 continues





P2903.5 continued

defined in both the IRC and IPC as a valve or faucet that closes automatically where released manually or controlled by mechanical means for fast-action closing. Because of all the variables related to different pipping systems, it is difficult to precisely define a quick-closing valve or to determine the valve closure speed that will result in water hammer. Such precision would require an analysis of the individual water-piping system. Washing machine and dishwashing machine solenoid valves are often considered as being "quick-closing" valves that require water hammer arrestors.

The prescriptive language to require water hammer arrestors when quick-closing valves are utilized has been reinstated in the 2018 IRC, and the code once again aligns with the corresponding section of the IPC, Adding the mandatory language reinforces the idea that all water distribution systems are susceptible to water hammer and a water hammer arrestor may be required in every water system. A water hammer arrestor decreases hydraulic shock by absorbing most of the energy from the change in velocity. The IPC defines a water hammer arrestor as a device utilized to absorb the pressure surge (water hammer) that occurs when water flow is suddenly stopped in a water supply system.

Proponents of the change stated that modern plumbing systems require water hammer control even more so than in the past. The advent of plastic piping systems, with various designs of metal and hard-plastic mechanical fitting systems, causes concern that these systems need protection from damaging pressure surges due to their lower pressure ratings compared to traditional metal piping systems. There is a wide variety of ASSE 1010-certified arrestors on the market, including laundry boxes with certified integral arresters.

WATER HAMMER FROM A DIFFERENT ANGLE

By Michael Meagher

August 1, 2009

A recent case study involved a severe water hammer problem in a fountain refill piping system at the City Hall Building in Grandview, MO (a suburb of Kansas City). The system consisted of a long run of 1-1/2" copper tubing leading up to a solenoid valve in a utility room within the city hall building itself. On the non-pressure side of the valve, 1-1/2" PVC piping exited the building underground and ran 100 feet to the fountain pool outside. A float switch in the pool controlled the solenoid valve back in the utility room. No other valves, before or after, were being operated. Each time this valve cycled off, a large bang emanated from the valve and echoed throughout the building.

Previously, the city hall maintenance engineer had a water hammer arrester installed on the pressure side of the valve. Proper installation requirements for sizing and placement of the arrester were followed. However, the arrester seemed to have little effect on the loud hammer upon each valve closure. Eventually, the destructive water hammer created a large crack in the PVC threaded adapter on the non-pressure line, six feet downstream of the valve, causing a noticeable leak inside the utility room.

A local plumbing contractor, Morgan-Miller Plumbing, was then called in to analyze the situation and fix the problem. At first, this fitting failure was a bit puzzling. Under normal water hammer situations, one would naturally expect the failure to occur on the pressure side of the valve. That's why arresters are usually required on the pressure side of valves. But in this case, the arrester was found to be working just fine, with no significant pressure surges upstream of the valve. This failure was definitely on the downstream side of the valve. The joint leak in the fountain refill line seemed to be a small steady drip most of the time. However, at the precise moment immediately following valve closure, a very high-pressure water spray was observed coming from the cracked fitting, just for a split second, accompanied by a loud bang. This momentary high-pressure spray on the non-pressure line was the telltale clue confirming exactly what the problem was. A quick high-pressure surge on the downstream side of the valve after valve closure could only be caused by one thing: a vaporous cavitation.

Cavitation occurs when water pressure is lowered below its vapor pressure. Water will literally flash or vaporize, forming small entrained bubbles (water vapor in its gaseous state) in the line directly after the quick-closing valve. In situations like the City Hall piping system, three factors play a role in this cavitation; high velocity, pipe length and quick valve closure. When the valve closes, the momentum of flow pulls a vacuum on the area immediately after the valve, constricting the pipe. If the velocity is high enough, the water column can cavitate.




If you have ever done any pressure surge calculations, you may recognize the same three factors that cause water hammer on the pressure side of the valve are the same factors that can cause cavitation on the non-pressure side. That's not a coincidence. The momentum energy in the flowing water is equal on both sides of the valve. When a valve is installed in the middle of the piping run rather than the end, the non-pressure run will contain a significant amount of kinetic energy as well.

It is important to note that water temperature is certainly an essential factor in the physics of cavitation and the vapor pressure of water. Hot water will flash to vapor easier than will cold water. However, in this City Hall case, and in most other plumbing-related cases studied, the cavitation problems developed in an ordinary cold-water piping system where temperature control or temperature change was not a factor.

The damaging effects of cavitation occur when momentum of the flowing water is dissipated and the entrained vapor bubbles collapse back to their liquid state. The rest of the non-pressure water column is then drawn back to fill this void at a super high velocity. An extremely high-pressure surge (water hammer) results after the high velocity water column slams into the valve (Figure 2). In lab tests of similar piping arrangements, pressure surges caused by cavitation have been measured up to 1,100 psig.

A water hammer arrester installed on the pressure side of the valve works great to control the energy in the water column upstream of the valve, but does nothing to prevent the cavitation and severe pressure surge on the downstream side. Even installing a second water hammer arrester after the valve will not help, because conventional arresters are not designed to prevent this specific problem or to absorb the resultant shock. A unique product called a vacuum arrester was introduced a few years ago to control this problem of cavitation. Similar in design to a piston-style water hammer arrester, the vacuum arrester temporarily breaks the vacuum that is pulled just beyond the closing valve. The operation of a vacuum arrester is functionally opposite of a conventional water hammer arrester.

The vacuum arrester has a much lower charge and the piston starts high in the barrel and travels down. When installed directly after the valve, the air in the vacuum arrester will expand to allow a more gradual stop of the water flow, and, thus, prevent cavitation.

In the Grandview City Hall piping system, the contractor correctly diagnosed the problem, installed a vacuum arrester and repaired the cracked fitting. Once a vacuum arrester was installed in addition to the water hammer arrester, the fountain system operated safely and quietly without any damaging pressure surges on either the pressure side or non-pressure side of the valve.

Unlike common atmospheric vacuum breakers, a vacuum arrester employs a contained pressure chamber that will never spit or leak water, nor will it ever allow air to be introduced into the water line. However, a vacuum arrester is not a traditional backflow prevention device and should not be substituted for one in other applications where those devices are required by code.



RESIDENTIAL & LIGHT COMMERCIAL WATER HAMMER CONTROL

AA-size piston-type arresters provide the solution to preventing water hammer in both residential and commercial applications.

Excerpt from April 2002 PM Engineer Magazine.

AA-size water hammer arresters are now sweeping the country as the permanent and affordable solution to that age-old problem of banging pipes and system damage caused by water hammer pressure surges, but this progress has been a long time in the making. Like many things in our industry, change doesn't happen overnight. Process and product innovation, industry education, along with new product standards and codes, have led the way.

In the 1980s, several arrester manufacturers offered a better alternative to plain air chambers when they introduced their single-fixture size arresters to the marketplace. At first, the use of these new arresters was somewhat limited due to the lack of official recognition at the codes and standards level. That all changed in 1996 when ASSE officially added the single-fixture AA-size category to the other six A through F arrester sizes in their ASSE 1010 Standard. Within 12 months, no less than three manufacturers had received ASSE certification on their compact and more affordable AA sizes, or double-A arresters, as they are now called.

Since then, the installation of AA arresters to control water hammer has grown tremendously throughout the country. Code officials in many states see the AA arrester as a very simple, very feasible way to address this water hammer control issue they've been struggling with for years. And not surprisingly, a large number of plumbing contractors report they are installing AA arresters even on applications where they are not required by code. They say arresters add quality to their jobs and help reduce callbacks. The AA size is considered a singlefixture arrester and it is designed for installation on a plumbing faucet or fixture at the point of use. In other words, one AA arrester should be placed on both the hot and cold lines as close as possible to each culprit valve or faucet that causes hammer.

The most common applications for AA arresters are on the water lines serving washing machines, dishwashers, and tub/shower valves. Historically, these areas have caused the most problems or have been the areas reported most often as having water hammer. At the very least, these three applications should always have AA arresters installed during new construction. Other possible applications on new construction or retrofit could be just about any other faucet or fixture in the plumbing system if water hammer is apparent, such as kitchen or lav faucets, water closets, and even ice maker valves.

A common myth is that one large arrester centrally located will control hammer throughout the piping system. In reality, this does little or nothing to control hammer. The arrester loses its effectiveness the farther away from the valve it is installed. Installation within six feet of the valve may work fine. However, when the arrester is installed 20 or 30 feet upstream, it has little effect. Arresters work like shock absorbers on a car. Your car has four wheels, so you need no less than four shocks, one placed at each wheel (point of use). Imagine the damage and abuse your car would take if it didn't have four properly placed shock absorbers. Your plumbing system is subject to the same type of abuse without proper arrester installation and placement.

Another question often asked is whether arresters are necessary on plastic tubing. Water hammer is a concern regardless of piping material, metal or plastic. It may be true that plastic tube does not seem to transmit as much noise as copper, but the energy from the flowing water is still there. It has to go somewhere. As a matter of fact, plastic tubing has a slightly smaller inner diameter compared to the same nominal size copper, so the flowing water has a higher velocity, which means even more energy to be absorbed when the flow is stopped. Upon valve closure, plastic tubing expands minutely which does absorb a small amount of this energy, but water hammer can still occur at flow rates of three or four gallons per minute. Many contractors install arresters on plastic tubing systems to alleviate the tubing and joints of any undue stress and strain, rather than the plastic system taking the full brunt of the pressure surge all by itself.



Even though the AA size is often thought of as residential, it can certainly be specified for commercial projects as well. Its ASSE listing and fixture-unit rating of 4 makes it ideal for sizing and specification on projects such as hotels, motels, or multi-family. For example, a common mistake in hotel arrester sizing and placement is specifying one large multi-fixture arrester centrally located between several rooms. Worse yet, sometimes one arrester is specified to cover an entire floor. No matter how large the arrester is, the centrally located placement will not suffice. Large multi-fixture arresters work great on a commercial rest room with a bank of fixtures all on the same header: but when the branch lines go off in many directions, like in a hotel, smaller arresters placed at the point of use would be a better solution.

To insure proper water hammer control on this type of project, specify a pair of AA arresters at each tub/shower valve (a common water hammer culprit). For the typical hotel back-to-back bathroom configuration, one pair of AAs will suffice for both valves (see below) since the chance of simultaneous shut-off of both valves is almost nil.

The product innovation of AA arresters has created dramatic effects at the code level as well. In the past five years, there have been major code revisions concerning water hammer control. In 1996, IAPMO published its UPC Installation Standard IS 20-96 for CPVC piping systems, which required arresters on all solenoid valves supplied with CPVC tubing. When this was first published, the UPC had yet to require arresters on other piping materials.

Then in 1997, IAPMO added Section 609.10 Water Hammer Control to the main body of the Uniform Plumbing Code, and then updated it in the UPC-2000 revision. This section calls out the requirement of listed mechanical devices on all quick closing valves in all potable water systems. It does not make exceptions for any piping material CPVC, copper, PEX or otherwise. Because of this new water hammer control requirement covering all piping systems, including CPVC, the secondary reference to water hammer control in the CPVC Installation Standard was deleted in 1998, evidently due to redundancy.

The International Plumbing Code (IPC-2000) also has a very similar requirement for water hammer control in its Section 604.9. AA arresters conforming to the ASSE 1010 Standard fulfill the product requirements of this code as well. IPC states that arresters should be installed per manufacturer's instructions. Therefore, if the arrester manufacturer states its arrester can be installed without access, then no access panels are required. Several states are already enforcing this section, and other states are planning to do so this year.

Location	Name of Job	Units
	Correctional Facilities	
Calipatria, CA	Northern Imperial County State Prison	54
Chowchilla, CA	Madera State Prison	1132
Coalinga, CA	Coalinga State Prison	480
Corcoran, CA	Corcoran Prison	188
Crescent City, CA	Del Norte California State Prison	813
Delano, CA	California State Prison	970
Oroville, CA	F.M. Booth Butte County Jail	44
San Mateo, CA	West County Detention Center	76
Santa Paula, CA	Ventura County Jail	415
Wasco, CA	State Prison	1012
Denver, CO	Women's Correction Facility	300
Niantic, CT	Womens Institution	500
Gainesville, FL	Alachua County Detention Center	160
Miami, FL	South Florida Reception/Correction Center	102
Orlando, FL	Central Florida Reception/Correction Center	98
Thomasville, GA	Thomas County Jail	138
Decatur, GA	DeKalb County Jail	465
Ina, IL	Rend Lake Correctional Center	750
Harrisburg, IL	Saline County Jail	160
Peoria, IL	Sheridan, Canton – Cell Houses	732
Kokomo, IN	Howard County Prison	322
Noblesville, IN	Hamilton County Juvenile Detention Center	15
El Dorado, KS	El Dorado Maximum Security Prison	160
Ellsworth, KS	Ellsworth Correctional Facility	161
Emporia, KS	Lyons County Law Enforcement Center	50
Lansing, KS	Kansas State Prison	118
Larned, KS	Larned State Correctional Facility Hospital	46
Wichita, KS	Sedgewick County Jail	526
Manchester, KY	Federal Correctional Institute	559
Warren, ME	Maine State Prison – Minimum Security	165
Baraga, MI	Baraga Correctional Facility	245
Greene County, MS	Southern Mississippi Correctional Facility	212
Monrovia, NY	New York State Maximum Security Facility	193
New York, NY	Metro Jefferson Correctional Facility	288
Portland, OR	Donald E. Long Juvenille Justice Center	128
Allenwood, PA	Allenwood Correction Center	340
Pittsburgh, PA	Allegheny County Jail	2000
Dauphin, PA	Dauphin County Prison	189
Waynesburg, PA	Green County Jail	665
Ridgeland, SC	Ridgeland Prison	126
-	Turbeville Prison	208
Turbeville, SC		
Abilene, TX	French Robertson Unit-Texas Dept.	933
Amarillo, TX	Amarillo Prison	992

Name of Job	Units
County Detention Center	83
Substance Abuse Treatment Facility	121
TDCJ Brownfield Prison	149
Gray County Jail Addition	30
Bowie County Jail	55
Substance Abuse Treatment Facility	103
McLennan County Jail	76
Roanoke City Jail	30
Deerfield Correction Center	34
Racine Correctional Institute	35
Oshkosh Correctional Center	427
Medical Facilities	
Druid City Hospital	235
Atascadero State Hospital	100
Bakersfield Memorial Hospital	230
Eisenhower Medical Center	55
Kaiser Hospital	124
Healdsburg General Hospital	20
Kaiser Hospital	477
Sierra View Hospital	90
New Britian Hospital	115
University Medical Center	50
Florida Hospital Addition	73
Flyod Hospital	20
Kootenai Medical Center	20
New State Hospital	115
Eastern Maine Medical Center(MRI Bldg.)	19
Miles Hospital	43
Crow Agency Hospital	80
Pitt County Hospital	190
Clinical Service Building	750
Rocky Mount Hospital	48
VA Medical Center	50
UNC Women & Children's Hospital	582
Wake Medical Center	150
Bryan Memorial Hospital Outpatient Building	165
Loveless Multi-Practice Hospital	40
Tioga Hospital / Nursing Home	111
	000
Slocum Dickson Medical Clinic	200
Slocum Dickson Medical Clinic Riverside Hospital	570
Riverside Hospital	570
Riverside Hospital Correction Medical Center	570 88
	County Detention Center Substance Abuse Treatment Facility TDCJ Brownfield Prison Gray County Jail Addition Bowie County Jail Substance Abuse Treatment Facility McLennan County Jail Roanoke City Jail Deerfield Correction Center Racine Correctional Institute Oshkosh Correctional Center Medical Facilities Druid City Hospital Atascadero State Hospital Bakersfield Memorial Hospital Eisenhower Medical Center Kaiser Hospital Healdsburg General Hospital Sierra View Hospital Sierra View Hospital New Britian Hospital University Medical Center Florida Hospital New Britian Hospital Sierra View Hospital New Britian Hospital Corow Agency Hospital Eastern Maine Medical Center(MRI Bldg.) Miles Hospital Crow Agency Hospital Crow Agency Hospital Pitt County Hospital Viles Hospital Clinical Service Building Rocky Mount Hospital VA Medical Center UNC Women & Children's Hospital Wake Medical Center Bryan Memorial Hospital Outpatient Building Loveless Multi-Practice Hospital

Location	Name of Job	Units
Greenwood, SC	Self Memorial Hospital	89
Bristol, TN	Bristol Regional Medical Center	240
Greenville, TN	Laughlin Hospital	200
Nashville, TN	Centennial Medical Center	285
Bonham, TX	VA Hospital	190
Lubbock, TX	Methodist Hospital	48
Houston, TX	Cypress Fair Womens Medical Center	76
Houston, TX	Kingwood Hospital	123
Tyler, TX	East Texas Medical Center	95
Suffolk, VA	Lakeview Medical Center	32
Norfolk, VA	Childrens Hospital	215
Fort Lewis, WA	Maddigan VA Hospital	398
Milwaukee, WI	Milwaukee City Medical Complex	32
Milwaukee, WI	Childrens Hospital of Wisconsin	350
Charleston, WV	CAMC Hospital	156
	Schools	
Pomona, CA	Pomona College	51
New Britain, CT	Central Connecticut State University	145
Palm Beach Garden, FL	Eissey Theatre, Palm Beach Comm. College	20
Atlanta, GA	Georgia Industrial Institute	146
Atlanta, GA	University Apartments (96 Olympics)	410
Iowa City, IA	Hillcrest Dormitory	96
Pekin, IL	CB Smith School	50
Bloomington, IL	Indiana University- Sports and Rec Building	48
Bloomington, IN	Monroe County High School	50
Indianapolis, IN	Center Grove High School	52
Indianapolis, IN	North Central High School	36
Indianapolis, IN	Indianapolis Public School 14, #269	61
Jasper, IN	Ireland Elementary	46
Muncee, IN	Burris School	50
Las Vegas, NV	Cheyenne High School	34
Las Vegas, NV	Memorial High School	34
Greensboro, NC	NCAT University Dorm Renovation	105
Brooklyn, NY	Brooklyn Occupational Training Center	60
Brooklyn, NY	Public School IS# 171	25
Buffalo, NY	University of Buffalo Housing	360
Oxford, OH	University Commons	128
Guthrie, OK	Guthrie Elementary School	31
Norman, OK	Oklahoma University Energy Center	72
Altoona, PA	Blairsville, High School	30
Erie, PA	Erie County VOTEC	35
Landisville, PA	Hemsfield High School	94
Moscow, PA	Moscow Elementary School	40
Saint Matthews, SC	John Ford Middle School	68

		пропал
Location	Name of Job	Units
Aiken, SC	Aiken High School Gym	43
Highland Park, TX	Highland Park Middle School	50
Houston, TX	Spring Branch Elementary School	100
College Station, TX	New Junior High School	43
Grapevine, TX	Grapevine/Colleyville ISD Elementary School	37
Lubbock, TX	Texas Tech. Univ. Health Sciences Building	96
Leesburg, VA	Lowden County Schools	78
Midlothian, VA	Bailey's Bridge High School	95
Sopkane, WA	Chase Middle School	48
Spokane, WA	Hamblen School	140
Antigo, WI	Antigo High School	25
Madison, WI	Beloit Memorial High School	32
	U.S. Military	
Fort Ord, CA	Military Housing	1142
Fresno, CA	Lemoore Naval Station	840
Twenty-Nine Palms, CA	U.S. Marine Corp Base	584
Denver, CO	Lowry AFB – Military Housing	368
Ft. Walton Beach, FL	Eglin AFB – Military Housing	505
Ft. Walton Beach, FL	Hurlburt Field – Military Housing	482
Mayport, FL	Rebault Bay Village Military Housing	1232
Panama City, FL	Coastal Dining Facility	40
Sorrento, FL	Patrick Air Force Base – Housing	250
Fort Benning, GA	Military Housing	456
St. Mary's, GA	King's Bay Submarine Base	164
Moanalua, HI	Military Base	1292
Pearl City, HI	Military Base	780
Schofield, HI	Military Housing	148
Glenview, IL	Glenview Naval Airbase	400
Fort Riley, KS	Military Housing	50
Bossier, LA	Barstow AFB – Military Housing	100
Camp Lejeune, NC	Bachelors Enlisted Quarters	426
Fort Bragg, NC	Military Housing	1156
Fort Bragg, NC	Military Housing (Barracks)	238
Fort Bragg, NC	Military Housing	528
Eatontown, NJ	Fort Monmouth Army Military Base	58
Clovis, NM	Cannon AFB Dorm	35
Holman, NM	Holman AFB – Enlisted Housing	740
Watertown, NY	Fort Drum – Military Housing	182
Altus, OK	Altus AFB – Military Housing	426
Fort Sill, OK	Military Housing	671
Fort Sill, OK	Barracks Renovation	264
Columbus, OH	DCSC Operation Center	272
Mechanicsburg, PA	Naval Control Parts Center	61
Newport, RI	Naval Education & Training Center	660
	-	

Location	Name of Job	Units
Box Elder, SD	Ellsworth AFB – Military Housing	1620
San Antonio, TX	Military Housing	284
Fort Hood, TX	Military Housing	176
Fort Hood, TX	Barracks Renovation	176
Shepherd, TX	Enlisted Dormitory	762
Fort Belvoir, VA	Army Military Housing	1328
Fort Belvoir, VA	Army Military Housing	79
Williamsburg, VA	Dormitory Training Facility, Camp Perry	61
Woodbridge, VA	Navy Apartments Village #1 and #3	706
McChord, WA	McChord AFB	300
Yakima, WA	Military Housing	400
	State/Federal Government	
Fairbanks, AK	HUD 40	80
Novato, CA	Fire Station	30
Redwood Valley, CA	Northern Circle Indian Housing Authority	50
Augusta, GA	Delta Homes (HUD)	250
Cartersville, GA	Cartersville Housing Authority (HUD)	150
Marietta, GA	Marietta Housing Authority (HUD)	130
Honolulu, HI	Helemano Government Housing Project	340
Wichita, KS	Kansas State Office Building	70
Landover, MD	Sommerfield Housing Project	2021
Bath, ME	West Bath District Court House	17
St. Louis, MO	Convention Center Addition	57
Box Eldr, MT	Indian Housing Authority	80
Sparks, NV	Pyramid Lake Indian Housing Authority	70
Pittsburgh, PA	Crowley Manor Housing Project (HUD)	330
Charleston, SC	Charleston Ship Yard (Public Works Facility)	35
Coyce, SC	U. S. Postal Office	55
Effingham, SC	Florence Civic Center	460
0	Hospitality	
Ocean Springs, AL	Sleep Inn Hotel	65
Boynton Beach, FL	Marriott Hotel	100
Ft. Lauderdal, FL	Comfort Suites Hotel	29
Kissimmee, FL	All-Star Resort	1296
Lake Buena Vista, FL	Magnolia Bend Disney Hotel	528
Orlando, FL	Clarion Hotel	338
Orlando, FL	Comfort Suites Hotel	120
Orlando, FL	Omni Rosen Hotel	236
Honolulu, HI	Hapuna Beach Hotel	45
Rockfork, IL	Econo-Lodge	100
Malden, MA	Gateway Hotel	336
Lansing, MI	Quality Inn Hotel	240
Traverse City, MI	Park Place Motel	80
Branson, MO	Holiday Inn	250
		200

Location Name of Job Units Branson, MO Seven Gables Motel 40 Branson, MO Green Mountain Inn 35 Holiday Hill Resort 48 Branson, MO Branson, MO Grand Victorian Inn 60 Osage Beach, MO Marriott Tan Tara 40 Las Vegas, NV MGM Grand Hotel 150 Durham, NC Hilton Hotel 92 Corning, NY Perri's Days Inn 64 Oklahoma City, OK Marriott Hotel 191 Myrtle Beach, SC Beach Cove Inn Motel/Hotel 520 40 Hilton Head, SC Grande Ocean Resort Chesepeake, VA Marriott Hotel 33 Ayudhya, Thailand Krung Sri Riverside Hotel 39 Bangkok, Thailand Amarit Watergate Hotel 47 Bangkok, Thailand Ayothaya Thani Hotel 633 Bangkok, Thailand Bai Yok Tower II 22

>> 660-SERIES

MiniRester™

SPECIFICATION

Sioux Chief 660 Series piston-type water hammer arresters shall be required in piping systems. Water hammer arresters shall be AA size to control water hammer caused by quick-closing valves on residential fixtures. Arresters shall be effective when installed at any angle. Arresters shall be approved for installation with no access panel required. Water hammer arresters shall be ANSI/ASSE 1010 2004 certified. Arresters shall be sized and placed per manufacturer's instructions.

MATERIALS

Arrester body: type L copper tube (660-G2B body is 304 stainless steel)
 Piston: poly piston with two EPDM o-rings
 Fitting: no-lead brass or copper
 Piston lubrication: Dow-Corning, 111 FDA approved silicone compound

WORKING LIMITS*

Max working temperature: 250°F Max working pressure: 250 PSIG Burst tested: to 1,500 PSIG *PEX and CPVC connection specifications are limited to those called out in their respective ASTM Standards for Fittings (CPVC D2846, PEX F1807 & F1960).

INSTALLATION

Angle: May be installed at any angle Access panels: No access panels required Sweat connection: Compatible with Press Fittings or Push Fittings

SIZING & PLACEMENT

Refer to instructions on product package, catalog or website.

CERTIFICATIONS/APPROVALS

Certified by ASSE to the ANSI/ASSE 1010-2004 standard, AA size cUPC listed to UPC and Canadian codes and standards

DIMENSIONS

	Male Thread	Male Sweat	Male CPVC	CPVC Socket	F1807 PEX	F1960 PEX	Viega PEX	Push Fitting
Arrester size	AA	AA	AA	AA	AA	AA	AA	AA
Overall height	33⁄8"	61⁄2"	4¼"	33⁄8"	41/4"	51/4"	51/4"	51/4"
Chamber width	7⁄8"	7⁄8"	7⁄8"	7⁄8"	7⁄8"	7⁄8"	7⁄8"	7⁄8"
Connection size	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
Volume (cu. in.)	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Fixture units	1-4	1–4	1–4	1-4	1-4	1–4	1–4	1–4

ITEM # SUBMITTED	
JOB NAME	
LOCATION	
ENGINEER	
CONTRACTOR	
PO# TAG	





multiple connection options available





Choose Item Number

G60-G2B = AA size, MIP
G60-SB = AA size, sweat
□ 660-V82B = AA size, male CPVC
□ 660-V2B = AA size, CPVC socket

- □ **660-X2B** = AA size, F1807 PEX □ **660-WG2B** = AA size, F1960 PEX
- □ 660-GVPX2B = AA size, Viega PEX
- □ 660-Q2B = AA size, push fitting

Sioux Chief

>> 660-GTR SERIES

SPECIFICATION

Sioux Chief 660-GTR piston-type water hammer arresters shall be installed where required on supply valves. Water hammer arresters shall be specifically sized and have sufficient volume of air to dissipate the calculated kinetic energy generated by closing residential or commercial faucets or valves. Arresters shall be installed on both hot and cold lines on the supply stops where applicable. Arresters shall be approved for installation with no access panel required.

MATERIALS

Arrester body: 304 stainless steel Piston: polypropylene with two EPDM o-rings Tee body: nickel-plated no-lead machined brass

WORKING LIMITS

Max working temperature: 250°F Max working pressure: 250 PSIG Burst tested to: 1,500 PSIG

INSTALLATION

Install MiniRester compression connections to supply stops and supply lines. Approved for installation with no access panels required.

CERTIFICATIONS/APPROVALS

Certified by ASSE to the ANSI/ASSE 1010-2004 standard, AA size cUPC listed to UPC and Canadian codes and standards

DIMENSIONS

	1⁄4'' OD	3∕8 '' OD	5⁄8 '' OD
Overall height	4"	4"	41/4"
Trunk width	2"	2"	21⁄2"

ITEM # SUBMITTED______ JOB NAME______ LOCATION ______ ENGINEER______ CONTRACTOR______ PO#_____ TAG _____







LEAD FREE COMPLIANT 1010

Choose Item Number

□ **660-GTR0B** = ¹/₄" OD compression × female compression □ **660-GTR1B** = ³/₈" OD compression × female compression □ **660-GTRB** = ⁵/₈" OD compression × female compression

MiniRester[™]



>> 650 SERIES

HydraRester[™]

SPECIFICATION

Sioux Chief 650 Series piston-type water hammer arresters shall be required in piping systems. Water hammer arresters shall have sufficient volume of air to dissipate the calculated kinetic energy generated in the piping system. Arresters shall be effective when installed at any angle. Arresters shall be approved for installation with no access panel required. Water hammer arresters shall be ANSI/ASSE 1010 2004 certified. Arresters shall be sized and placed per manufacturer's instructions.

INSTALLATION

May be installed at any angle. No access panels required. Compatible with Press Fittings or Push Fittings. Refer to instructions on product package, catalog or website.

MATERIALS

Arrester body: type L copper tube
Piston: poly piston with two EPDM o-rings
Male thread fitting: copper MIP thread
Piston lubrication: Dow-Corning, 111 FDA approved silicone compound
PEX F1960 fitting: No Lead EcoBrass 69300

CERTIFICATIONS/APPROVALS

Certified by ASSE to the ANSI/ASSE 1010-2004 standard

WORKING LIMITS*

Max working temperature: 250° Max working pressure: 350 PSIG Burst tested: to 2,900 PSIG

*PEX and CPVC connection specifications are limited to those called out in their respective ASTM Standards for Fittings (CPVC D2846, PEX F1807, PEX 1960).

DIMENSIONS

Arrester size	Α	В	С	D	Е	F
Overall height						
Male thread	61⁄2"	8¾"	11"	101/8"	125/8	15½"
Male sweat	81/4"	10"	12½"	11"	131/2"	16"
CPVC	7½"	9½"	12"	_		
PEX F1807	61⁄2"	8¾"	11"	_		
PEX F1960	61⁄2"	8¾"	11"	_		
Chamber width	13⁄8"	13⁄8"	13⁄8"	21/8"	21/8"	21/8"
Connection size	1/2"	3⁄4"	1"	1"	1"	1"
Volume (cu. in.)	5	7	11	20	29	36
Fixture units	1–11	12–32	33–60	61–113	114–154	155–330

ITEM # SUBMITTED______ JOB NAME______ LOCATION ______ ENGINEER______ CONTRACTOR______ PO#_____TAG _____











Choose Item Number

 G52-A = A size, MIP G53-B = B size, MIP G54-C = C size, MIP G55-D = D size, MIP G56-E = E size, MIP G57-F = F size, MIP 	 652-AS = Sweat/Press-Fit 653-BS = Sweat/Press-Fit 654-CS = Sweat/Press-Fit 655-DS = Sweat/Press-Fit 656-ES = Sweat/Press-Fit 657-FS = Sweat/Press-Fit 	 G52-AX = A size, PEX 1807 G53-BX = B size, PEX 1807 G54-CX = C size, PEX 1807 G52-AWG = A size, PEX 1960 G53-BWG = B size, PEX 1960 G54-CWG = C size, PEX 1960 	 □ 652-AC = A size, CPVC socket □ 653-BC = B size, CPVC socket □ 654-CC = C size, CPVC socket
657-F = F size, MIP	□ 657-FS = Sweat/Press-Fit	□ 654-CWG = C size, PEX 1960	
	G56-ES = Sweat/Press-Fit	□ 653-BWG = B size, PEX 1960	

Sioux Chief

>> 658 SERIES

SPECIFICATION

Sioux Chief 658 Series piston-type water hammer arresters shall be installed where required in piping systems. Water hammer arresters shall have sufficient volume of air to dissipate the calculated kinetic energy generated in the piping system. Arresters shall have a permanently sealed tube body with factory air charge, and shall be available with male thread or flanged connection. Arresters shall be sized and placed per manufacturer's instructions.

MegaRester[™]

MATERIALS

Arrester body Copper/brass: 4¹/₈" O.D. type L copper tube Stainless steel: 4¹/₄" O.D. 316 stainless steel tube

Male thread fitting

Copper/brass: wrought copper fitting (ANSI B1.20.1), lead-free solder joint **Stainless steel:** 316 stainless steel fitting (ANSI B1.20.1), welded flange

Flange

Copper/brass: cast brass flange (ANSI B16.24), lead free solder joint **Stainless steel:** 316 stainless steel flange (ANSI B16.24), welded **Piston:** acetal piston, dual EPDM o-rings lubricated with Dow 111, FDA-approved silicone compound. **Gauge:** 600 lb. liquid-filled

WORKING LIMITS

Max working temperature: 250°F Max working pressure: 350 PSIG Burst tested: to 2,900 PSIG

DIMENSIONS

	Height (with gauge)
658-1503	23.25"
658-2002	29.25"
658-2004	24.50"
658-4004	42.50"
658-4004F2	41.75"
658S2002	24.25"
658S2004F2	24.00"
658S4004F2	40.00"

ITEM # SUBMITTED
JOB NAME
LOCATION
ENGINEER
CONTRACTOR
PO# TAG

658S4004F2



Choose Item Number

658-1503 = copper, 3" MIP, 150 in³
 658-2002 = copper, 2" MIP, 200 in³
 658-2004 = copper, 4" MIP, 200 in³
 658-4004 = copper, 4" MIP, 400 in³

- □ **658-4004F2** = copper, 4" flange, 400 in³
- □ 658S2002 = stainless steel, 2" MIP, 200 in³
- \Box 658S2004F2 = stainless steel, 4" flange, 200 in³
- □ 658S4004F2 = stainless steel, 4" flange, 400 in³



Notes:			

Sioux Chief Manufacturing

Warranty

Sioux Chief Mfg. Co., Inc. ("Seller" or "the Seller") warrants its products to be free from defects in material and workmanship under normal usage for the lifetime of the plumbing system in which they were originally incorporated. In the event of such defects within the warranty period, the Company will, at its option, replace or recondition the product without charge. This remedy shall be effective only if the product was installed in accordance with supplied instructions, common installation or use practices and existing building and plumbing codes and legal requirements; has not been subjected to misuse or abuse; was at all times used in a manner consistent with its intended use; was at all times used in installations and environments acceptable to its material and design specifications; was never modified, altered or repaired by anyone other than the Seller; was properly subjected to and passed common testing methods (including pressure testing for potable water and drainage systems) immediately after the product's installation and before the product is put into service; was not damaged by freezing, corrosion, degradation or other adverse water, atmospheric or other natural conditions; was never subjected to improper protection during the installation or exposure to water pressures or temperatures outside acceptable operating conditions. In addition, Seller shall not be responsible for any incidental, special or consequential damages, including without limitation, lost profits or the cost of repairing or replacing other property which is damaged, other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, chemical or any other circumstances over which the Seller has no control. This warranty excludes all costs arising from routine maintenance, including the replacement of any parts required by such maintenance and the replacement of parts required by normal wear and tear. The Seller also reserves the right to modify, alter or improve its product, or parts thereof, at any time without incurring an obligation to notify or modify, alter, improve or replace any product, or parts thereof, previously sold. If, on any occasion, Seller waives any term or condition, this waiver is not to be construed as a continuing waiver. For the purposes of this warranty, the lifetime of the original plumbing system is defined as the lesser of 25 years or the time before the plumbing system was replaced or materially changed; all products with automatically or manually moving parts are excluded from the limited lifetime warranty and carry a 3-year limited warranty, subject to the remaining terms, conditions and limitations of the warranty. Some States do not allow or have other parameters governing limitations on how long an implied warranty lasts, and some States do not allow the exclusion or limitation of incidental or consequential damages. This Limited Warranty gives you specific legal rights, and you may have other rights that vary from State to State. You should consult applicable state laws to determine your rights. THE WARRANTY SET FORTH HEREIN ABOVE AND BELOW IS GIVEN EXPRESSLY AND IS THE ONLY WARRANTY GIVEN BY THE COMPANY WITH RESPECT TO THE PRODUCT. THE COMPANY MAKES NO OT HER WARRANTIES, EXPRESS OR IMPLIED. THE COMPANY HEREBY SPECIFICALLY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

Terms & Conditions

All sales are subject to the Standard Terms and Conditions set forth on Sioux Chief's website at www. siouxchief.com. These terms include the following:

Returned Goods

No material shall be returned without authorization. When credit is issued it will be at the price charged, less handling charges based on costs of reconditioning, boxing, etc. Products that are obsolete or made to special order are not returnable. No merchandise will be accepted by Seller as a return unless such return is authorized in writing by Seller.

Returned Goods & Warranty Service

In order to return product or receive warranty service, customers must obtain a Return Goods Authorization ("RGA") by contacting Seller using the following information:

MAIL: Customer Service Manager Sioux Chief Manufacturing Company, Inc. 14940 Thunderbird Road Kansas City, Missouri 64147

PHONE: 816-425-9900 / 1-800-821-3944

FAX: 816-348-7502 / 1-800-758-5950

EMAIL: info@siouxchief.com

Returned Goods Procedure

RGA requests must reference Seller's order number, invoice number or the customer's P.O. number, and must be less than twelve months old.

In order to be received, all returned material must be in multiples of the stated catalog minimum order quantity and in original condition.

Specials or custom-made products are not considered normal stock and therefore cannot be returned, except in case of manufacturer's defect.

Customers will be charged 25% of invoice price for product restocking.

RGA is invalid if referenced product is not received within 90 days of an RGA issue date.

Issuance of the RGA does not authorize the customer to deduct the value of the return; once product is received by Seller and found to be in acceptable condition, Seller will issue a credit memo for returned product when applicable.

Seller reserves the right to deny, nullify or cancel an RGA at its discretion.

Seller will only supply product credit for a return or warranty claim.

Seller can reject a return for any reason at any time.

Warranty Procedure - Product & Property

If there is a warranty claim on a part that involves property or other damage, Seller should be contacted by phone or in writing directly following the loss, and in no case later than 15 days of the date of alleged claim or failure and before any remediation or alteration of the loss site has been started; any notice beyond this time frame or after work has taken place to repair or change the loss site will materially affect the Seller's ability to adjudicate the claim and will void the warranty. The product in claim and/or its installation should not be modified before review by Seller; alteration of the alleged product or installation materially affects the Seller's ability to establish fault and voids the warranty.

Upon submitting the claim according to this procedure and timing, claimant will receive a RGA number from Seller.

With the RGA number, claimant should submit a formal report of the claim, including the date of the installation, a description of the problem and damage and pictures of the product and damage (if possible). This information should be sent to the above address at claimant's expense. Seller will not receive or process a claim without an RGA number.

Seller will contact claimant with next steps, which may include a visit from a site investigator or other representatives of Seller, as Seller reserves the right to investigate all alleged loss sites.

Seller shall not be responsible for shipping errors reported 5 days after receipt of material.

Seller shall not be responsible for shipment shortages that are signed for as clear.

Full Freight Allowance

Sioux Chief will pay freight on all orders to single destinations totaling at least \$2,000 net to locations within the 48 contiguous states (United States of America), at least \$2,500 net to locations within Hawaii, Alaska, and Puerto Rico, and at least \$2,000 CAD net to locations within Canada.

Processing of Orders

All orders are processed immediately upon receipt and acceptance by Seller. Seller reserves the right to charge back to Buyer costs incurred from order cancellations or changes, and to consider additions as separate orders.

Price Changes

All prices quoted from time to time by Seller are subject to change without notice up to time of shipment. Invoice totals and discounts will be calculated out to the fourth decimal digit. If Buyer fails to give written notice of objection to Sioux Chief's order confirmation within ten (10) days after Buyer's receipt of Sioux Chief's confirmation of the purchase order, the order confirmation pricing becomes binding.

Minimum Order Quantities

A 10% surcharge will be applied to any item not purchased in multiples of the stated Minimum Quantity, except on drop-ship orders. Items with bold Minimum Quantities in the Numerical Index (back of catalog) can never be broken.

TAKE THE FIELD.

www.siouxchief.com

14940 Thunderbird Road Kansas City, M0 64147 P 1.800.821.3944 F 1.800.758.5950 #LT1-ENGRPT 1-21

