

CPVC STRAPS



FUNCTION: Designed to support CPVC pipe horizontally from the side or bottom of beam, or composite wood joists with a minimum of 3/8" web thickness. Fig. 076 can only be used as a guide on top of beam or on vertical piping. Fig. 076 may be installed onto wood using supplied fasteners or into, minimum 18 gauge, steel using two 1/4" X 1" tek type screws. Features flared edges to protect piping as it slides through the installed fitting.

SIZE: 3/4" (20) through 2" (50) CPVC pipe


FINISH: Pre-galvanized

MATERIAL: Carbon Steel

APPROVALS: Underwriters Laboratories listed for US and Canada

ORDERING: Specify pipe size and model number.

Fig. 076
CPVC TWO-HOLE
STAND OFF STRAP



Pipe Size	A		B		D		Material Size		Box Qty.	Max. Spacing		Appx. Wt. Per 100	
										ft.	m	lbs.	kg
3/4	(20)	2 ⁹ / ₁₆	(65.09)	4 ¹ / ₄	(107.95)	1.050	(26.67)	20ga. x 1 ¹ / ₈ "	(.79 x 28.58)	100	5.5	(1.68)	12.10 (5.49)
1	(25)	2 ¹³ / ₁₆	(71.44)	4 ¹ / ₂	(114.30)	1.315	(33.40)	20ga. x 1 ¹ / ₈ "	(.79 x 28.58)	100	6	(1.83)	12.80 (5.81)
1 ¹ / ₄	(32)	3 ³ / ₁₆	(80.96)	4 ⁵ / ₈	(117.48)	1.660	(42.16)	20ga. x 1 ¹ / ₈ "	(.79 x 28.58)	100	6.5	(1.98)	14.10 (6.40)
1 ¹ / ₂	(40)	3 ⁷ / ₁₆	(87.31)	5	(127.00)	1.900	(48.26)	20ga. x 1 ¹ / ₈ "	(.79 x 28.58)	100	7	(2.13)	15.20 (6.89)
2	(50)	3 ⁷ / ₈	(98.43)	5	(127.00)	2.375	(60.33)	20ga. x 1 ¹ / ₈ "	(.79 x 28.58)	100	8	(2.44)	16.40 (7.44)

20ga. = 0.035" nominal

Unless otherwise specified, all dimensions on drawings and in charts are in inches and dimensions shown in parentheses are in millimeters.



PHD Manufacturing, Inc.

44018 Columbiana-Waterford Road

Columbiana, Ohio 44408-9481

Phone: 800-321-2736 • 330-482-9256


Fax: 330-482-2763

Web: www.phd-mfg.com

FIGURE 076 INSTALLATION INSTRUCTIONS

FUNCTION: Designed to support CPVC pipe horizontally from the side or bottom of beam, or composite wood joists with a minimum of 3/8" web thickness. **Fig. 076 can only be used as a guide on top of beam or on vertical piping.** Fig. 076 may be installed onto wood using supplied fasteners or into, minimum 18 gauge, steel using two 1/4" X 1" tek type screws. Features flared edges to protect piping as it slides through the installed fitting.

ORIENTATIONS:



SUPPORT



GUIDE


APPROVALS: Underwriters Laboratories listed for US and Canada

MATERIAL: Carbon Steel Fitting and two #10 X 1" hardened unslotted indented hex head self threading screws

FINISH: Pre-galvanized G-90

WARNINGS: The safety of the total system involves a system designer, installer, and user. The manufacturer has limited or no control over such factors as environmental conditions, total system design, product selection, and maintenance. The installer is responsible for the application to conform to local codes, the integrity of attaching structure, and the use of proper fasteners. Failure to follow these specifications may result in product malfunction. All load ratings are for static conditions and neglect dynamic loading of any kind. Observe all safety regulations for your surroundings while installing.

INSTALLATION: Clip strap around CPVC pipe and squeeze strap back around pipe to size noted below, or slide over end of pipe. Fig. 076 should slide freely on pipe. Then orient and mount strap to surface where applicable taking into account the maximum spacing allowed between straps. Install in compliance with NFPA 13 and local codes. **DO NOT** use impact tools when installing. No pre-drilling is required when utilizing supplied fasteners.



Pipe Size	A	B	D Nominal	Material Size	Max Spacing
3/4	2 5/8	3 1/2	1.050	20 ga. X 1 1/8"	5'-6"
1	2 15/16	3 1/2	1.315	20 ga. X 1 1/8"	6'-0"
1 1/4	3 1/4	3 1/2	1.660	20 ga. X 1 1/8"	6'-6"
1 1/2	3 1/2	3 1/2	1.900	20 ga. X 1 1/8"	7'-0"
2	3 15/16	4	2.375	20 ga. X 1 1/8"	8'-0"