

WHITLAM FROST-PROOF *GL48* 48% Glycerine

Anti-Freeze and Heat Transfer Fluid



- Formulated for CPVC Systems
- NFPA Compliant
- Premixed Anti-Freeze
- Burst Protection to -50°F (-46°C)
- Generally Regarded as Safe

AVAILABLE SIZES:

Stock#	Size
Plastic Jug with Spout	
FPGL1	1 Gal. (3.785 L)
Pail with Handle	
FPGL5	5 gal. (18.9 L)
55 Gallon Steel Drum	
FPGL55	55 gal. (208 L)
275 Gallon Plastic Tote	
FPGL275	275 gal. (1041 L)

FROST-PROOF GL48 Anti-Freeze is a non-toxic, glycerine based anti-freeze for all types of wet fire sprinkler systems, including CPVC, that provides burst protection to -50°F (-46°C). **FROST-PROOF GL48** is a 48% pre-blend that conforms to NFPA standards to allow for direct replacement of anti-freeze in the system. No dilution is required.

FROST-PROOF GL48 is nonflammable and non-corrosive. **FROST-PROOF GL48** will not support bacterial growth in the system and eliminates the possibility of contaminating domestic and potable water systems. **FROST-PROOF GL48** Anti-Freeze Solution is "Generally Recognized as Safe" (GRAS) by the Federal Food and Drug Administration. All fire protection systems that use **FROST-PROOF GL48** need to conform to local, state and NFPA requirements.

FROST-PROOF GL48, when used undiluted, will protect against freeze damage and ensures flow in the system. See freeze protection chart below.

% of FROST-PROOF <i>GL48</i>	Freeze Point	Flow Point	Burst Point	Specific Gravity @77°F / 25°C
100%	15°F (-9°C)	-25°F (-32°C)	-50°F (-46°C)	1.137



J.C. Whitlam Mfg. Co.
P.O. Box 380
Wadsworth, OH
44282-0380
U.S. & Canada
Phone: 800-321-8358
Fax: 800-537-0588
International
Phone: 1-330-334-2524
FAX: 1-330-334-3005



FBC™ System Compatible indicates that this product has been tested, and is monitored on an ongoing basis, to assure its chemical compatibility with FlowGuard Gold®, BlazeMaster® and Corzan® pipe and fittings. FBC™, FlowGuard Gold®, BlazeMaster®, and Corzan® are licensed trademarks of the Lubrizol Corporation.

www.frostproofgl.com



FROST-PROOF GL48

Anti-Freeze for CPVC Fire Suppression Systems

NFPA Compliant • Generally Regarded as Safe (GRAS)
Suitable for use on BlazeMaster® and FlameGuard™
CPVC Fire Suppression Systems

Burst Protection: -50°F (-46°C)

Flow Protection: -25°F (-32°C)

Freeze Protection: 15°F (-9°C)

FROST-PROOF GL48 Anti-Freeze is a non-toxic, glycerine based anti-freeze for all types of wet fire sprinklers systems, including CPVC, that provides burst protection to -50°F (-46°C). **FROST-PROOF GL48** is a 48% pre-blend that conforms to NFPA standards to allow for direct replacement of anti-freeze in the system. No dilution is required.

FROST-PROOF GL48 is nonflammable and non-corrosive. **FROST-PROOF GL48** will not support bacterial growth in the system and eliminates the possibility of contaminating domestic and potable water systems.

FROST-PROOF GL48 Anti-Freeze Solution is “Generally Recognized as Safe” (GRAS) by the Federal Food and Drug Administration. All fire protection systems that use **FROST-PROOF GL48** need to conform to local, state and NFPA requirements. **FROST-PROOF GL48** when used undiluted, will protect against freeze damage and ensure flow in the system. See freeze protection chart below.

DIRECTIONS FOR USE:

1. Empty the entire system through faucets, petcocks, and other openings; then close all openings.
2. Replace all liquid with an equal amount of **FROST-PROOF GL48** to obtain -50°F (-46°C) burst protection. Do not add any additional water or concentrated glycerine to the system.
3. After filling the system, follow NFPA guidelines for testing the system. Fluid samples should be tested from both a low and high point on the system.
4. NFPA requires a service tag to be affixed to the riser indicating; the date last tested or replaced, type and concentration of fluid in system, total volume of the system, contractor responsible for servicing the system (include license number), and statement indicating the entire system was drained and replaced with **FROST-PROOF GL48**.
5. **FROST-PROOF GL48** can remain in the system all year. NFPA 25 requires that the freeze point of the anti-freeze be tested annually before the onset of freezing weather.

Due to the molecular structure of glycerine all connections in the system must be completely sealed and air tight to avoid seepage of the solution. All fire protection sprinkler systems that use **FROST-PROOF GL48** must conform to local, state and NFPA requirements. Disposal of **FROST-PROOF GL48** should be in conformance with national, state and local health codes. Biodegradation under aerobic static laboratory conditions is high (BOD20 or BOD28/ThOD greater than 40 percent). It is expected that biodegradation will be achievable in a secondary wastewater treatment plant.

% of FROST-PROOF GL48	Freeze Point	Flow Point	Burst Point	Specific Gravity @77°F / 25°C
100%	15°F (-9°C)	-25°F (-32°C)	-50°F (-46°C)	1.137



J.C. Whitlam Manufacturing Company
200 West Walnut Street
Wadsworth, OH 44281
Phone: 1-330-334-2524
www.frostproofGL.com



WHITLAM
The Industry Standard for Over 100 Years

BlazeMaster® is a registered trademark of The Lubrizol Corporation.
FlameGuard™ is a registered trademark of Spears Manufacturing Company.