

WHITLAM

FROST-PROOF PG38

38% Propylene Glycol

Anti-Freeze and Heat Transfer Fluid



- Formulated for Metal Fire Lines
- NFPA Compliant Glycol
- Premixed Anti-Freeze
- Burst Protection to -50°F (-46°C)
- Generally Regarded as Safe

AVAILABLE SIZES:

Stock#	Size
Plastic Jug with Spout	
FPPG1	1 gal. (3.785 L)
Pail with Handle	
FPPG5	5 gal. (18.9 L)
55 Gallon Steel Drum	
FPPG55	55 gal. (208 L)
275 Gallon Plastic Tote	
FPPG275	275 gal. (1041 L)



J.C. Whitlam Mfg. Co.
P.O. Box 380
Wadsworth, OH
44282-0380
U.S. & Canada
Phone: 800-321-8358
Fax: 800-537-0588
International
Phone: 1-330-334-2524
FAX: 1-330-334-3005

FROST-PROOF PG38 Anti-Freeze is a non-toxic, propylene glycol based anti-freeze for all types of wet fire sprinkler systems, excluding CPVC, that provides burst protection to -50°F (-46°C). **FROST-PROOF PG38** is a 38% pre-blend that conforms to NFPA standards to allow for direct replacement of anti-freeze in the system. No dilution is required.

FROST-PROOF PG38 is nonflammable and non-corrosive. **FROST-PROOF PG38** will not support bacterial growth in the system and eliminates the possibility of contaminating domestic and potable water systems. **FROST-PROOF PG38** Anti-Freeze Solution is "Generally Recognized as Safe" (GRAS) by the Federal Food and Drug Administration. All fire protection systems that use **FROST-PROOF PG38** need to conform to local, state and NFPA requirements.

FROST-PROOF PG38, when used undiluted, will protect against freeze damage and ensures flow in the system. See freeze protection chart below.

% of FROST-PROOF PG38	Freeze Point	Flow Point	Burst Point	Specific Gravity @77°F / 25°C
100%	0°F (-18°C)	-15°F (-26°C)	-50°F (-46°C)	1.05



www.frost-proof.com

FROST-PROOF PG38

Anti-Freeze for Wet Fire Suppression Systems*

**NFPA Compliant • Generally Regarded as Safe (GRAS)
Formulated for Wet Metal Fire Sprinkler Systems***

**Burst Protection: -50°F (-46°C)
Flow Protection: -15°F (-26°C)
Freeze Protection: 0°F (-18°C)**

FROST-PROOF PG38 Anti-Freeze is a non-toxic, propylene glycol based anti-freeze for all types of wet fire sprinkler systems that provides burst protection to -50°F (-46°C). **FROST-PROOF PG38** is a 38% pre-blend that conforms to NFPA standards to allow for direct replacement of anti-freeze in the system. No dilution is required.

FROST-PROOF PG38 is nonflammable and non-corrosive. **FROST-PROOF PG38** will not support bacterial growth in the system and eliminates the possibility of contaminating domestic and potable water systems.

FROST-PROOF PG38 Anti-Freeze Solution is "Generally Recognized as Safe" (GRAS) by the Federal Food and Drug Administration. All fire protection systems that use **FROST-PROOF PG38** need to conform to local, state and NFPA requirements. **FROST-PROOF PG38** when used undiluted, will protect against freeze damage and ensure flow in the system. See freeze protection chart below.

DIRECTIONS FOR USE:

1. Empty the entire system through faucets, petcocks, and other openings; then close all openings.
2. Replace all liquid with an equal amount of **FROST-PROOF PG38** to obtain -50°F (-46°C) burst protection. Do not add any additional water or concentrated propylene glycol to the system.
3. After filling the system, follow NFPA guidelines for testing the system. Fluid samples should be tested from both a low and high point on the system.
4. NFPA requires a service tag to be affixed to the riser indicating; the date last tested or replaced, type and concentration of fluid in system, total volume of the system, contractor responsible for servicing the system (include license number), and statement indicating the entire system was drained and replaced with **FROST-PROOF PG38**.
5. **FROST-PROOF PG38** can remain in the system all year. NFPA 25 requires that the freeze point of the anti-freeze be tested annually before the onset of freezing weather.

Due to the molecular structure of propylene glycol all connections in metallic pipe must be completely sealed and air tight to avoid seepage of the solution. All fire protection sprinkler systems that use **FROST-PROOF PG38** must conform to local, state and NFPA requirements. Disposal of **FROST-PROOF PG38** should be in conformance with national, state and local health codes. Biodegradation under aerobic static laboratory conditions is high (BOD20 or BOD28/ThOD greater than 40 percent). It is expected that biodegradation will be achievable in a secondary wastewater treatment plant.

% of FROST-PROOF PG38	Freeze Point	Flow Point	Burst Point	Specific Gravity @77°F / 25°C
100%	0°F (-18°C)	-15°F (-26°C)	-50°F (-46°C)	1.037



J.C. Whitlam Manufacturing Company
200 West Walnut Street
Wadsworth, OH 44281
Phone: 1-330-334-2524
www.frost-proof.com



WHITLAM

The Industry Standard for Over 100 Years