

## **Detail Property Tax Information**


Disclaimer: The tax information was updated on 9/14/2020. Please notify the Treasurer's Office of any inaccuracies. Online Tax Billing History is available from Tax Year 2000 forward. If you wish information for prior tax years contact the Treasurer's Office. Pay Taxes Online

Tax ID: D13017 Tax Year: 2019 ELDERGROVE

Code	District	1st Half	2nd Half Total
	ELDERGROVE (Levy District)	888.15 P	888.14 P 1,776.29
CRED	CRED COUNTY REFUSE DISTRICT	10.00 P	10.00 P 20.00
LUFS	LUFS LRL URBAN FIRE SERV AREA	62.50 P	62.50 P 125.00
SOIL	SOIL SOIL CONSERVATION	0.55 P	0.55 P 1.10
	Totals	961.20	961.19 1,922.39

Date Paid 11/07/2019 04/09/2020

Close Window





## STATE OF MONTANA DEPARTMENT OF ENVIRONMENTAL QUALITY CERTIFICATE OF SUBDIVISION APPROVAL (Section 76-4-101 et. seq., MCA)

TO: County Clerk and Recorder Yellowstone County Billings, Montana

E.Q. # 05-2910 Y.C. #2424

THIS IS TO CERTIFY THAT the plans and supplemental information relating to the subdivision known as TRACT 2-B of TRACT 2, 2ND AMENDED, CERTIFICATE OF SURVEY 894 (SMITH GIFT TO FAMILY), being a portion of Tract 2, situated in E1/2 NW1/4 of SECTION 24, T.1S., R.24E., P.M.M., YELLOWSTONE COUNTY, MONTANA, consisting of 1 parcel have been reviewed by personnel of the Permitting and Compliance Division, and,

(SEE EXHIBIT "A" FOR METES AND BOUNDS DESCRIPTIONS)

THAT the documents and data required by ARM Chapter 17 Section 36 have been submitted and found to be in compliance therewith, and,

THAT approval of the CERTIFICATE OF SURVEY (COS) of subdivision is made with the understanding that the following conditions shall be met:

THAT Parcel sizes as indicated on the COS to be filed with the county clerk and recorder will not be further altered without approval, and,

THAT TRACT 2-B shall be used for ONE SINGLE-FAMILY DWELLING, and,

THAT the individual water system will consist of a WELL drilled to a minimum depth of 25 feet and/or a CISTERN constructed in accordance with the criteria established in Title 17, Chapter 36, Sub-Chapters 1, 3, and 6, ARM and the most current standards of the Department of Environmental Quality, and,

THAT data provided indicates an acceptable water source at a depth of 35-50 feet, and,



PAGE 2 of 3 COS 894 TR. 2-B CLEMENS SMITH YELLOWSTONE CO.

Chapter 36, Sub-Chapters 1, 3, and 6 ARM, and,

THAT each subsurface drainfield shall have an absorption area of sufficient size to

provide 750 square feet of trench for a three (3) bedroom dwelling, and,

THAT the individual sewage treatment system will consist of a septic tank with effluent filter and subsurface drainfield of such size and description as will comply with Title 17,

THAT the bottom of the drainfield shall be at least four feet above the water table, and,

THAT no sewage treatment system shall be constructed within 100 feet of the maximum highwater level of a 100 year flood of any stream, lake, watercourse, or irrigation ditch, nor within 100 feet of any domestic water supply source, and,

THAT water supply and sewage treatment systems will be located as shown on the approved plans, and,

THAT all sanitary facilities must be located as shown on the attached lot layout, and,

THAT the developer shall provide the purchaser of property with a copy of the Plat, approved location of water supply and sewage treatment system as shown on the attached lot layout and a copy of this document, and,

THAT instruments of transfer for this property shall contain reference to these conditions, and,

THAT plans and specifications for any proposed sewage treatment systems will be reviewed and approved by the Yellowstone City-County Health Department and will comply with Yellowstone City-County Board of Health Rule #3 and Title 17, Chapter 36, Sub-Chapters 3 and 9, ARM, before construction is started.

PAGE 3of 3 COS 894 TR. 2-B CLEMENS SMITH YELLOWSTONE CO.



3350793 Page: 3 of 4 09/30/2005 03:40P

THAT departure from any criteria set forth in the approved plans and specifications and Title 17, Chapter 36, Sub-Chapter 1, 3, and 6 ARM when erecting a structure and appurtenant facilities in said subdivision without Department approval, is grounds for injunction by the Department of Environmental Quality.

Pursuant to Section 76-4-122 (2) (a), MCA, a person must obtain the approval of both the State under Title 76, Chapter 4, MCA, and local board of health under section 50-2-116(1)(i), before filing a subdivision plat with the county clerk and recorder.

YOU ARE REQUESTED to record this certificate by attaching it to the Certificate of Survey of said subdivision filed in your office as required by law.

DATED this 1st day of June, 2005.

RICHARD OPPER DIRECTOR

REVIEWED AND APPROVED:

ΓED (XYLANDER, R.S.

ENVIRONMENTAL HEALTH PROGRA

YCCHD

RAY LAZUK, SUPERVISOR

SUBDIVISION SECTION

PERMITTING & COMPLIANCE DIVISION DEPARTMENT OF ENVIRONMENTAL

**QUALITY** 

OWNERS NAME: CLEMENS SMITH

