

LOT 21


Case Number: WHA SEP 2020 - 02326

PIN 9756-73-4606

BUNCOMBE COUNTY DEPARTMENT OF HEALTH  
ENVIRONMENTAL HEALTH SERVICES (828-250-5016)  
IMPROVEMENT PERMIT FOR WASTEWATER SYSTEM CONSTRUCTION

Property Owner: Clyde Smith Property Location: 11 Ivy Knoll Lane Application Date: 12/17/20  
Directions: Barnesville Hwy, left on Ivy Hill, left on Ivy Meadows Drive  
Subdivision: Ivy Meadows Lot# 21

Water Supply: ☒ Private Well ☐ Shared Well ☐ Spring ☐ Municipal ☐ Public/Community Existing Wells: ☐ Yes ☒ No  
Minimum Separation Distance to Well (includes system and repair area): 50 ft  
System Design: ☐ Residential ☐ Commercial Multiple Unit Dwelling: No. of Units \_\_\_\_\_ Bedrooms/per unit \_\_\_\_\_ Max. # of occupants/per unit \_\_\_\_\_  
☒ House ☐ Mobile Home (☐ single ☐ double) Bedrooms 3 Max. # of occupants 6 Basement: ☐ Yes ☒ No Basement Plumbing: ☐ Yes ☒ No  
Soil Group: TD LTAR: 0.35 Design Flow: 360  
System Type: ☐ Prefabricated Panel Block ☐ Conventional ☐ Large Diameter Pipe ☒ Chamber ☒ Expanded Polystyrene Aggregate ☐ Other \_\_\_\_\_



\_\_\_\_\_ This permit is valid only for a structure of this description or smaller  
☒ This permit is not limited to a structure of this description; however, no part of the structure shall extend into the designated area for the sewage treatment system  
An Authorization to construct must be obtained when final plans are completed and exact type and location of building are established. For planning purposes, please be aware that building, driveways, excavation, fill dirt, or other obstruction may not be placed or constructed in any part of the area designated for the sewage treatment system. This permit is subject to revocation if the site is altered or the intended use changes from those described above.  
A Building permit may not be issued until an Authorization to Construct is obtained

Issued By: [Signature] Date: 2/15/21 Owner/Agent: \_\_\_\_\_ Date: \_\_\_\_\_

THIS IMPROVEMENT PERMIT IS VALID FOR 5 YEARS FROM THE DATE OF ISSUANCE